



MICHELLE LUJAN GRISHAM
GOVERNOR

JAMES C. KENNEY
CABINET SECRETARY

Certified Mail- Return Receipt Requested (Certified #: 7021 1970 0002 0164 1407)

Notice of Intent to Red Tag: Class B Violation(s)
20.5.116 NMAC Delivery Prohibition

Date: February 13, 2024

To: SOM Incorporated (Owner ID# 14256)
1666 South University Blvd. Ste B., Denver, CO 80210
Holly@bradleyGas.com

GS & K Brothers LLC DBA Save O Mart (Operator ID# O13607)
1855 8th St., Las Vegas, NM 87701

Re: Sav O Mat (Facility ID# 30490, NOV# 16 20211005 3225)
745 S 2nd St, Raton, NM 87740

Date of NOD: December 14, 2021

Following an inspection on October 05, 2021 by the New Mexico Environment Department's ("Department") Petroleum Storage Tank Bureau ("PSTB"), the facility noted above has been cited with Class B violation(s) pursuant to section 20.5.116.1601.B(1) and (2) of the Petroleum Storage Tank Regulations, Title 20 Chapter 5 of the New Mexico Administrative Code ("NMAC"). The Department provided you with a Notice of Violation ("NOV") with the inspection report informing you of the violation(s) that were identified during the inspection and allowing 30 days from the date of the NOV to correct them. Because the violation(s) that were outlined in the NOV and inspection report were not corrected within the required timeframe, the Department issued a Notice of Deficiency ("NOD") on the date noted above (*see* "Date of NOD") re-stating the violation(s) that were identified during the inspection and providing you with an additional 30 days from the date of the NOD to correct the violation(s).

If these violation(s) listed in the table below are not corrected, a release to the environment could occur or a release could go undetected. In order to correct the violation(s) and come into compliance, please ensure that any corrective actions taken remain in compliance with 20.5 NMAC regulations. **If the violation(s) in the table are not corrected within 30 days from the date of this Notice of Intent to Red Tag, the subject tank(s) noted in the table will be classified as ineligible for delivery, deposit or acceptance of product, in accordance with 20.5.116.1602.B(3) NMAC.**

SCIENCE | INNOVATION | COLLABORATION | COMPLIANCE

Violations included in this action:

Violation Code	Tank ID(s)	Violation Description
20.5.107.705.C NMAC	30250, 30251, 30253	Failure to inspect the equipment of an impressed current cathodic protection system installed on a UST system every 60 days
20.5.108.800.E NMAC	30253	Failure to provide release detection by monitoring monthly for releases on a UST system installed prior to April 4, 2008.
20.5.107.705.B(1)(a) NMAC	30250, 30251, 30253	Failure to test a cathodic protection system on a UST system within six months of installation and at least every three years thereafter

This means that, in accordance with 20.5.116.1603 NMAC, the following actions will occur:

- (a) PSTB will physically place red tag(s) prohibiting the delivery, deposit or acceptance of product on the fill port(s) of the tank(s) with the continuing Class B violation(s). The red tag(s) must remain affixed on the tank(s) until the violation(s) are corrected.
- (b) PSTB will post the name and address of this facility on its website list of facilities that are ineligible for delivery, deposit or acceptance of product.
- (c) PSTB will post a certificate, conspicuously displayed at the facility clearly prohibiting any delivery, deposit or acceptance of product at every storage tank at the facility to which the Department has affixed a red tag.

It shall be unlawful for any person, other than an authorized representative of the Department, to remove, tamper with, destroy or damage a red tag affixed to any storage tank or certificate posted at a storage tank facility by Department personnel (*see* 20.5.116.1603.C NMAC). Owners and operators shall continue to perform leak detection, corrosion protection, and monthly inspections, in addition to any other performance requirements in 20.5 NMAC, on the tanks that have a red tag (*see* 20.5.116.1603.D NMAC).

This facility is not located in a rural and remote area as defined in 20.5.101.7.R(14) NMAC and continued operation of the tank is not a matter of national security. If you believe that your facility is located in a rural and remote area as it is defined in the regulations and this Notice of Intent to Red Tag does not designate it as rural and remote, please contact the Department. If this facility is operated by the United States Department of Defense ("DOD"), DOD may notify the Department that continued operation of the tank(s) is a matter of national security. The PSTB will defer classifying this facility as ineligible for delivery for up to 180 days if it is designated as rural and remote or a matter of national security (*see* 20.5.116.1608 NMAC).

Please notify PSTB Inspector Joe Godwin at 505-699-4006 if you do not understand the violation(s) cited, or to notify PSTB of the schedule of when work is planned to be done in order to correct the violation(s). You are required to notify the PSTB of any installation, replacement, repair or modification (*see* 20.5.116.1602.D NMAC). ***The PSTB will work with you to ensure the violation(s) are in compliance with 20.5 NMAC and are corrected as soon as possible.***

Unless the violation(s) cited in this Notice of Intent to Red Tag are corrected, the facility may not be in compliance with the requirements and provisions of the Petroleum Storage Tank Regulations as required for eligibility for reimbursement from the Corrective Action Fund if your facility has a release (*see*

February 13, 2024
Notice of Intent to Red Tag - Class B Violation
Facility ID # 30490, NOV# 16 20211005 3225
Page 3

20.5.123.2303 NMAC). **If you have corrected the violation(s) cited in this Notice of Intent to Red Tag, please contact the PSTB inspector immediately.**

Thank you in advance for your attention to this matter.

Lorena Goerger Digitally signed by Lorena Goerger
Date: 2024.02.13 11:24:08 -07'00'

February 13, 2024

Lorena Goerger, Bureau Chief
Petroleum Storage Tank Bureau

Date

cc: Sav O Mat, 745 S 2nd St, Raton, NM 877404111
Jen Olson, Office of General Counsel, New Mexico Environment Department (via electronic transmission)
Jim Gibb, Program Manager, Remedial Action Program, Petroleum Storage Tank Bureau (via electronic transmission)
Allison Urbon, Project Manager, Remedial Action Program, Petroleum Storage Tank Bureau (via electronic transmission)
Joe Godwin, Program Manager, Prevention Inspection Program, Petroleum Storage Tank Bureau (via electronic transmission)
Chris Hamilton, Supervisor, Prevention Inspection Program, Petroleum Storage Tank Bureau (via electronic transmission)
Van Lewis, Compliance Assistance Coordinator, Petroleum Storage Tank Bureau (via electronic transmission)
PSTB Master File
PSTB Owner File