



Notification provided via E-mail

September 20, 2023

Rebekah Bryant; rebekah@tularosa.net
Tularosa Water System, NM3514019
705 St. Francis Dr.
Tularosa, New Mexico 88352

**RE: Notice of Violation - Stage 2 Disinfection Byproducts Rule
Total Trihalomethanes (TTHM) Maximum Contaminant Level**

Dear Rebekah Bryant:

This letter serves as Notice of Violation that the Tularosa Water System exceeded the Locational Running Annual Average (LRAA) maximum contaminant level (MCL) for Total Trihalomethanes (TTHMs) at the TTHM-1 monitoring location during the 2nd quarter of 2023. The LRAA for the Tularosa Water System at the High School are shown in the table below:

Sample Location	Sample Date	Quarter & Year	TTHM LRAA (mg/L)
TTHM-1, High School	6/5/2023	2Q2023	0.083

The MCL for Total Trihalomethanes is 0.080 milligrams per liter (mg/L) at each individual sampling location. The MCLs for Total Trihalomethanes are defined in the New Mexico Drinking Water Regulations, 20.7.10.100 NMAC (incorporating 40 CFR Section 141.64(b)(2)(i)). The MCLs for Total Trihalomethanes are determined by calculating the locational running annual average (LRAA) pursuant to 20.7.10.100 NMAC, (incorporating 40 CFR 141.620(d)).

Based on the exceedance of the MCL for Total Trihalomethanes, the New Mexico Environment Department Drinking Water Bureau (DWB) requires the Tularosa Water System water system to notify customers of these MCL exceedances as required in 20.7.10.100 NMAC (incorporating 40 CFR Section 141.203(b)(1) and 141.203(b)(2)). The notice must be provided to all customers and others who drink the water within thirty (30) days from the date on this letter and must be issued every three (3) months as long as the exceedances persist. In addition, public notice must be provided by one other method reasonably expected to reach consumers of the water system, i.e., publication in a local newspaper or posting in conspicuous locations. This notice must remain posted as long as the violation persists.

Pursuant to 20.7.10.100 NMAC (incorporating 40 CFR Section 141.31(d)) the Tularosa Water System water system must certify that the notice was published and the method of publication, by submitting a completed copy of the enclosed Public Notification Certification Form to the DWB within 10 days. A representative copy of each type of notice distributed, published, posted or made available to the people served by the system must be included with the certification form.

Please fill out and return the enclosed Public Notice Certification Form to:

SCIENCE | INNOVATION | COLLABORATION | COMPLIANCE

Oneva Peña by email to nmenv.dbp@env.nm.gov

Failure to comply with the public notice requirements will result in an additional violation (failure to notify the public and the state) being issued without notice to the Tularosa Water System water system. Continued failure to comply with Public Notification Requirements, as defined in 20.7.10.100 NMAC (incorporating 40 CFR Sections 141.203 and 141.31(d)) will result in escalated enforcement actions including issuance of Administrative Orders with possible penalties assessed against the Tularosa Water System water system.


NMED-DWB reserves the right to take additional enforcement action regarding the violations identified in this NOV, to include the issuance of an Administrative Compliance Order compelling compliance and issuing civil penalties.

Pursuant to the NMED Delegation Order dated March 24, 2023, the Cabinet Secretary has delegated the authority to issue Notice of Violations to DWB Bureau Chief Joe R. Martinez.

Please note that your facility will appear on the Department's Enforcement Watch as a result of this NOV (see: <https://www.env.nm.gov/enforcement-watch/>). Further, the Department will issue a press release to local media highlighting your public water system as appearing on this webpage. Your public water system will remain on the Enforcement Watch website as an active matter until this matter is fully resolved.

If you have any questions or need assistance, please contact Oneva Peña at 505-490-5363 or by e-mail at nmenv.dbp@env.nm.gov.

Respectfully,

A handwritten signature in blue ink that reads "Joe R. Martinez". The signature is stylized and cursive.

Joe R. Martinez, Bureau Chief
Drinking Water Bureau
Water Protection Division

Enclosures: Public Notice Template
 Public Notice Certification Form

xc: Brandi Littleton, Southern Area Compliance Supervisor (electronic)
 Electronic Central File

Public Notice Instructions for Stage 2 TTHM MCL Violation

Template on Following Page

If your system's locational running annual average for Total Trihalomethanes (TTHM) exceeds the MCL of 0.080 mg/L or the locational running annual average for Haloacetic Acid (HAA5) exceeds the MCL of 0.060 mg/L at one or more sampling locations, you must provide public notice to persons served as soon as practical but within 30 days after you learn of the violation 20.7.10.100 NMAC [incorporating 40 CFR 141.203(b)]. You must issue a repeat notice every three months for as long as the violation persists.

Community systems must use one of the following methods 20.7.10.100 NMAC [incorporating 40 CFR 141.203(c)]:

- Hand or direct delivery
- Mail, as a separate notice or included with the bill

Noncommunity systems must use one of the following methods 20.7.10.100 NMAC [incorporating 40 CFR 141.203(c)]:

- Posting in conspicuous locations
- Hand delivery
- Mail

In addition, both community and noncommunity systems must use *another* method reasonably calculated to reach others if they would not be reached by the first method 20.7.10.100 NMAC [incorporating 40 CFR 141.203(c)]. Such methods could include newspapers, e-mail, or delivery to community organizations. If you mail, post, or hand deliver, print your notice on your system's letterhead, if available.

The notice on the reverse is appropriate for mailing, posting, or hand delivery. If you modify this notice, you must still include all required PN elements from 40 CFR 141.205(a) and leave the mandatory language unchanged (see below).

Mandatory Language

Mandatory language on health effects (from Appendix B to Subpart Q) must be included as written (with blanks filled in) and is presented in this notice in italics and with an asterisk on either end.

You must also include standard language to encourage the distribution of the public notice to all persons served, where applicable 20.7.10.100 NMAC [incorporating 40 CFR 141.205(d)]. This language is also presented in this notice in italics and with an asterisk on either end.

Corrective Action

In your notice, describe corrective actions you are taking. Listed below is one step commonly taken by water systems with TTHM or HAA5 MCL violations. You can include the following statement, if appropriate, or develop your own text:

- We are working to minimize the formation of [TTHM or HAA5] while ensuring we maintain an adequate level of disinfectant. We have taken additional steps to change disinfectant type/levels, remove natural organic matter, and increased flushing of water lines to determine if our efforts have been effective.

Repeat Notices

For repeat notices, you should state how long the violation has been ongoing and remind consumers of when you sent out any previous notices. If you are making progress, describe it. Alternatively, if funding or other issues are delaying progress, let consumers know.

After Issuing the Notice

Make sure to send The New Mexico Environment Department's Drinking Water Bureau a copy of each type of notice and a certification that you have met the public notice requirements within ten days after you issued the notice 20.7.10.100 NMAC [incorporating 40 CFR 141.31(d)].

****PUBLIC WATER SYSTEM MUST APPROPRIATELY MODIFY THIS PUBLIC NOTICE TO INCLUDE UP-TO-DATE INFORMATION REGARDING THE VIOLATION AS WELL AS INFORMATION ABOUT THE CURRENT STATUS OF THE VIOLATION'S AFFECT ON THE WATER SYSTEM. PUBLIC WATER SYSTEM OFFICIAL MUST DELETE THIS PARAGRAPH ONCE PUBLIC NOTICE HAS BEEN APPROPRIATELY UPDATED, PRIOR TO SENDING OUT TO THE PUBLIC****

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Tularosa Water System Has Levels of Total Trihalomethanes above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results show that our system exceeds the standard or maximum contaminant level (MCL), for Total Trihalomethanes. The standard for Total Trihalomethanes is 0.080 mg/L. The average level of Total Trihalomethanes over the last quarter is shown in the table below:

Sample Location	Sample Date	Quarter & Year	TTHM LRAA (mg/L)
TTHM-1, High School	6/5/2023	2Q2023	0.083

What should I do?

- There is nothing you need to do. You do not need to boil your water or take corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. However, some people who drink water containing Total Trihalomethanes in excess of the MCL over many years may have an increased risk of getting cancer. Additionally, some people who drink water containing Total Trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous systems.

What is being done?

[Describe corrective action.] We anticipate resolving the problem within [estimated time frame].

For more information, please contact:

Rebekah Bryant at 575-585-2771

Or

Tularosa Water System, NM3514019

705 St. Francis Dr.

Tularosa, NM 88352

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

