

From: [Herrmann, Grace](#)
To: [Romero, D.Renee, NMENV](#)
Cc: [Macneil, Katherine, NMENV](#); [Golden, Tom](#); [Morgan, York](#); [King, Christopher](#); [Hall, Gwinn](#); [Rice, Savannah](#); [Torres, Israel](#)
Subject: [EXTERNAL] Former Y Station - System Installation Weekly Progress Update
Date: Monday, February 21, 2022 8:24:04 AM
Attachments: [Former Y - Week 8 photos.pdf](#)

CAUTION: This email originated outside of our organization. Exercise caution prior to clicking on links or opening attachments.

Hi Renee,

This email serves as a summary of work completed at the Former Y Station in Clovis, NM for remediation system installation February 14-18, 2022. Due to strong winds and low temperatures that would have created unsafe and dusty work conditions, the crew did not work February 17-18.

The following tasks were accomplished:

- Excavated approximately 132 ft of conveyance trench.
- Placed conveyance piping (2" and 1.5" PVC) and electrical conduit (0.75" and 1.25" PVC) in open excavated trench.
- Backfilled and compacted open trench where conveyance pipe and conduit had been placed. Trenches were topped with base course.
- Installed wellhead vaults at MW-11 and MW-13 including installation of electrical conduit and conveyance piping.
- Used a brush attachment on the skid-steer loader to clean pavement in numerous areas of parking lot.
- Maintained completed trenches by adding base course to low spots and cleaning the parking lot areas as needed.
- Received truckload of 14" HDPE pipe for road borings.

The following work is planned for this week:

- Complete horizontal road borings across Commerce Way and N Prince St, including preparing boring pits.
- Complete trench excavation north to RW-3.
- Place conveyance piping and conduit in open trenches, complete inspections, and backfill open trenches.
- Place RW-3 wellhead and valve vaults as trenches are completed.
- Perform trenching and pipe installation on the Optical Source property outside of business hours.

I have attached photos of work at the site, which include comments to assist in interpretation. Please let me know if you have any questions.

Regards,

Grace Herrmann, EI
Staff Engineer

Daniel B. Stephens & Associates, Inc.

Hydrology | Engineering | Geoscience

A Geo-Logic Company

Providing solutions for water, natural resources, and the environment

6020 Academy Road NE, Suite 100 | Albuquerque, New Mexico 87109

T (505) 822-9400 | D (505) 353-9051 | M (505) 379-0934 | F (505) 822-8877

www.dbstephens.com