

# Cathodic Protection System Evaluation Form

- This form may be utilized to evaluate and report the results of testing cathodic protection systems in the State of New Mexico.
- Access to the soil directly over the cathodically protected structure that is being evaluated must be provided.
- A site drawing depicting the cathodic protection system and all reference electrode placements must be completed.

<input type="checkbox"/> Evaluation of Impressed Current System	<input type="checkbox"/> Evaluation of Galvanic (Sacrificial) Anodes	Date Test Conducted:
---	--	----------------------

### I. Facility Information.

Name:		Facility ID#:	
Address:		City:	Zip Code:
County	Phone Number		Email:

### II. Owner Information.

Name:		Owner ID#:	
Address:		City:	State:
Zip Code:	Phone Number		Email:

### III. Reason Evaluation was Conducted (mark only one)

- Routine - 3 year     
  Routine - within 6 months of installation     
  90 days after fail     
  After Repair/Modification

Date next evaluation must be conducted:	(within 6 months of installation/repair & every 3 years thereafter)
---	---

### IV. Description of Storage Tank System(s)

Tank #	Product	Capacity	Tank Material	Piping Material	Flex Connectors
1					
2					
3					
4					
5					
6					
7					
8					

### V. Cathodic Protection Tester's Evaluation (mark only one)

<input type="checkbox"/>	<b>PASS</b>	All protected structures at this facility pass the cathodic protection evaluation and it is judged that adequate cathodic protection has been provided to the storage tank system (indicate all criteria applicable by completion of Section VII).
<input type="checkbox"/>	<b>FAIL</b>	One or more protected structures at the facility fail the cathodic protection evaluation and it is judged that adequate cathodic protection has not been provided to the storage tank system (complete Sections IX and XII).
<input type="checkbox"/>	<b>Inconclusive</b>	If the remote and local do not have the same test results on all protected structures (both pass or both fail); inconclusive must be checked off and evaluation must be either evaluated or conducted by corrosion expert.

Tester's Name:		Company Name:	
Address:		City:	State:
Zip Code:	Phone Number		Email:

Certification Source:	Certification Level:	Certification Number:
Certification Expiration Date	CP Tester's Signature	Date Signed by Tester

**VI. Corrosion Expert's Evaluation (mark only one)**

The evaluation must be conducted and /or evaluated by a **Corrosion Expert** when: a) supplemental anodes or other changes in the construction of the cathodic protection system are made; b) stray current may be affecting buried metal structures, or c) an inconclusive result was written in Section VI. (except for under STI-R972 - "Recommended Practice for the Addition of Supplemental Anodes to Sti-P3 USTs")

<input type="checkbox"/>	<b>PASS</b>	All protected structures at this facility pass the cathodic protection evaluation and it is judged that adequate cathodic protection has been provided to the storage tank system (indicate all criteria applicable by completion of Section VII).
<input type="checkbox"/>	<b>FAIL</b>	One or more protected structures at the facility fail the cathodic protection evaluation and it is judged that adequate cathodic protection has not been provided to the storage tank system (complete Sections IX and XII).

Corrosion Expert's Name:		Company Name:	
Address:		City:	State:
Zip Code:	Phone Number	Email:	
Certification Source:	Certification Level:	Certification Number:	
Corrosion Expert's Signature		Date Signed	

**VII. Criteria Applicable to Evaluation (mark only one)**

<input type="checkbox"/>	<b>- 850mV ON / (Instant) OFF</b> (circle "ON" or "OFF" to Specify)	Structure-to-soil potential more negative than -850mV with respect to Cu/CuSO <sub>4</sub> reference electrode. This criterion is applicable to any galvanically protected structure" for the -850mV "ON". This criterion is applicable to galvanic systems where the anodes can be temporarily disconnected for the -850mV "OFF".
<input type="checkbox"/>	<b>100mV Polarization</b>	Structures(s) exhibit at least 100mV of cathodic polarization. This criteria is applicable to galvanic systems where the anodes can be temporarily disconnected for the 100mV polarization.
<input type="checkbox"/>	<b>Inconclusive</b>	The results of either the instant-off test or polarization shift are inconclusive as to whether the structures are protected.

**VIII. Evaluation of Flex Connectors and Buried Metal Risers**

<input type="checkbox"/>	<b>PASS</b>	All flex connectors and buried metal risers in contact with an electrolyte such as but not limited to soil or water are protected from corrosion by the installation of galvanic anodes that meet the requirements in Section VII.
<input type="checkbox"/>	<b>FAIL</b>	One or more protected flex connectors or buried metal risers fail the cathodic protection evaluation and it is judged that adequate cathodic protection has not been provided (complete Sections IX and XII).
<input type="checkbox"/>	<b>Isolated</b>	Flex connectors and buried metal risers are isolated from electrolytes and cathodic protection is not required.

**IX. Action Required as a Result of this Evaluation (mark only one)**

<input type="checkbox"/>	<b>NONE</b>	Cathodic protection is adequate. No further action is necessary at this time. Test again no later than (see Section III).
<input type="checkbox"/>	<b>RETEST</b>	Cathodic protection may not be adequate. Retest during the next 90 days to determine if passing results can be achieved.
<input type="checkbox"/>	<b>REPAIR &amp; RETEST</b>	Cathodic protection is not adequate. Repair / modification is necessary as soon as practical but within the next 90 days.

**X. Impressed Current Rectifier Data (complete all applicable)**

In order to conduct a effective evaluation of the cathodic protection system, a complete evaluation of rectifier operation is necessary.

Rectifier Manufacturer:				Rated DC Output; volts:		amps:	
Rectifier Model:			Rectifier Serial Number:				
Rectifier output as initially designed ro last recommended (if available); volts:						amps:	
Event	Date	Tap Settings		DC Output		Hour Meter	Comments
		Coarse	Fine	Volts	Amps		
"As Found"							
"As Left"							

**XI. Impressed Current Positive & Negative Circuit Measurements (output amperage)**

Complete if the system is designed to allow such measurements (i.e. individual lead wires for each anode are installed and measurement shunts are present).

Circuit	1	2	3	4	5	6	7	8	9	10	Total Amps
Anode (+)											
Tank (-)											

**XII. Description of Cathodic Protection System Repairs and/or Modifications**

<input type="checkbox"/>	Additional anodes for an impressed current system (attach corrosion expert's design) .
<input type="checkbox"/>	Supplemental anodes for a STI-P3 tank or metallic pipe (attach corrosion expert's design or documentation industry standard was followed).
<input type="checkbox"/>	Repairs or replacement of rectifier (explain in "Remarks/Other" below).
<input type="checkbox"/>	Anode header cables repaired and/or replaced(explain in "Remarks/Other" below).
<input type="checkbox"/>	Impressed current protected tanks/piping not electrically continuous (explain in "Remarks/Other" below).
<input type="checkbox"/>	Galvanically protected tanks/piping NOT electrically isolated (explain in "Remarks/Other" below).

Remarks and/or Comments on Repairs or Modifications.





**XV. Facility Site Drawing**

Attach detailed drawing of the storage tank systems and cathodic protection systems. Sufficient detail must be given in order to clearly indicate where the reference electrode was placed for each structure-to-soil potential that is recorded on the survey forms. Any pertinent data must also be included. At a minimum indicate the following: all tanks, piping and dispensers; all buildings and streets; all anodes and wires; location of CP test stations; and, each reference electrode placement must be indicated by a code followed by a "IC" or "G" to indicate the type of CP system (e.g., R1-IC, R2-G, etc.) corresponding with the appropriate line number in Section XIV of this form.

**AN EVALUATION OF THE CATHODIC PROTECTION SYSTEM IS NOT COMPLETE WITHOUT AN ACCEPTABLE SITE DRAWING.**