



MICHELLE LUJAN GRISHAM  
GOVERNOR

JAMES C. KENNEY  
CABINET SECRETARY

## PUBLIC NOTICE

# Groundwater Discharge Permit Applications Submitted to the Department for Review

### November 3, 2023

Dear Interested Party,

The New Mexico Environment Department (NMED) Ground Water Quality Bureau (GWQB) hereby provides notice pursuant to 20.6.2.3108 NMAC that the following Groundwater Discharge Permit applications have been submitted to NMED for review. Provided the applicant has met applicable requirements, NMED will propose for approval a Discharge Permit containing limitations, monitoring requirements, and other conditions intended to protect groundwater quality for present and potential future use.

NMED will accept comments and statements of interest regarding the application and will create a facility specific mailing list for persons who wish to receive future notices. NMED is developing a Public Involvement Plan (PIP) to provide public participation opportunities and information that may be needed for the community to participate in the permitting process. The PIP will be posted online at <https://www.env.nm.gov/public-notices/> and placed at the NMED field office nearest to the proposed permitted activity. To learn more about a Discharge Permit and the permitting process or to be placed on a facility-specific mailing list, please contact the NMED Permit Contact at the telephone number or email address provided or address correspondence to the GWQB, PO Box 5469, Santa Fe, NM 87502-5469.

In the future, NMED will publish a second public notice providing a draft permit and will seek public comment on the draft. You will be able to add the comment period to your calendar simply through our Events Calendar located at <https://www.env.nm.gov/events-calendar/>.

If you are a non-English speaker, do not speak English well, or if you have a disability, you may contact the NMED Permit Contact to request assistance, an interpreter, or an auxiliary aid in order to learn more about a Discharge Permit or the permitting process, or to participate in activities associated with the permitting process. To the extent possible, NMED will arrange for requested interpretation services and accommodations or services for persons with disabilities. Telephone conversation assistance is available through Relay New Mexico at no charge for people who are deaf, hard of hearing, or have difficulty speaking on the phone, by calling 1-800-659-1779; TTY users: 1-800-659-8331; Spanish: 1-800-327-1857. Telephone interpretation assistance for persons that are a non-English speaker or do not speak English well is available at no charge when calling NMED.

NMED does not discriminate on the basis of race, color, national origin, disability, age or sex in the administration of its programs or activities, as required by applicable laws and regulations. NMED is

Science | Innovation | Collaboration | Compliance

Ground Water Quality Bureau | 1190 Saint Francis Drive, PO Box 5469, Santa Fe, New Mexico 87502-5469  
Telephone (505) 827-2900 | [www.env.nm.gov/gwqb/](http://www.env.nm.gov/gwqb/)

responsible for coordination of compliance efforts and receipt of inquiries concerning non-discrimination requirements implemented by 40 C.F.R. Parts 5 and 7, including Title VI of the Civil Rights Act of 1964, as amended; Section 504 of the Rehabilitation Act of 1973; the Age Discrimination Act of 1975, Title IX of the Education Amendments of 1972, and Section 13 of the Federal Water Pollution Control Act Amendments of 1972. If you have any questions about this notice or any of NMED's non-discrimination programs, policies or procedures, you may contact: Kate Cardenas, Non-Discrimination Coordinator, New Mexico Environment Department, 1190 St. Francis Dr., Suite N4050, P.O. Box 5469, Santa Fe, NM 87502, (505) 827-2855, [nd.coordinator@env.nm.gov](mailto:nd.coordinator@env.nm.gov). If you believe that you have been discriminated against with respect to a NMED program or activity, you may contact the Non-Discrimination Coordinator identified above or visit our website at <https://www.env.nm.gov/general/environmental-justice-in-new-mexico/> to learn how and where to file a complaint of discrimination.

Enclosure: Groundwater Discharge Permit Applications Submitted for Review



### Discharge Permit: DP-934 South Slope Dairy

- County: Curry |Closest City: Clovis
- Applicant: SS Dairy Partners Ltd. Co., 499 CR 14, Clovis, NM 88101
- NMED Permit Contact: Keelyn Taylor, Water Resources Professional, [keelynl.taylor@env.nm.gov](mailto:keelynl.taylor@env.nm.gov) or [acs.general@env.nm.gov](mailto:acs.general@env.nm.gov), Telephone: 505-469-4764 or 505-827-2900

**Notice:** DP-934, South Slope Dairy: Jim Abacherli proposes to renew and modify the Discharge Permit for the discharge of up to 150,000 gallons per day of wastewater from the production area of a dairy facility. Potential contaminants from this type of discharge include nitrogen compounds. The facility and discharge locations are located at 499 CR 14, approximately 4 miles northeast of Clovis, in Sections 29, 30, and 32, Township 03 North, Range 37 East and Section 25, Township 03 North, Range 36 East, Curry County. Groundwater most likely to be affected is at a depth of approximately 380 feet and had a pre-discharge total dissolved solids concentration of 310 milligrams per liter.

### Discharge Permit: DP-47, Doña Ana MDWCA District 5 Wastewater Treatment Facility

- County: Doña Ana |Closest City: Las Cruces
- Applicant: Doña Ana MDWCA, Jennifer Horton, Executive Director, P.O. Box 866, Doña Ana, NM 88032
- NMED Permit Contact: Kambray Townsend, Water Resource Professional, [kambray.townsend@env.nm.gov](mailto:kambray.townsend@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-538-0497 or 505-827-2900.

**Notice:** DP-47, Doña Ana MDWCA District 5 Wastewater Treatment Facility: Doña Ana MDWCA proposes to renew the Discharge Permit for the discharge of up to 255,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 1100 Fairway Village Dr, Las Cruces, in Section 17 (projected), Township 23 South, Range 01 East, Doña Ana County. Groundwater most likely to be affected is at a depth of approximately 32.5 feet and had a pre-discharge total dissolved solids concentration of 1,700 milligrams per liter.

### Discharge Permit: DP-1525, San Mateo Enterprises Inc.

- County: Doña Ana|Closest City: Hatch
- Applicant: Rosie Lack, Owner, PO Box 769, Hatch, NM 87937
- NMED Permit Contact: Aracely Tellez, Water Resource Professional, [Aracely.Tellez@env.nm.gov](mailto:Aracely.Tellez@env.nm.gov) or [acs.general@env.nm.gov](mailto:acs.general@env.nm.gov), Telephone: 505-629-8864 or 505-827-2900.

**Notice:** DP-1525, San Mateo Enterprises Inc.: Rosie Lack proposes to renew the Discharge Permit for the discharge of up to 9,999 gallons per day of agricultural wastewater from a chile processing plant to a surface disposal area. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 7301 Highway 26, Hatch, in Section 29, Township 19 South, Range 4 West, Doña Ana County. Groundwater most likely to be affected is at a depth of approximately 150 feet and had a pre-discharge total dissolved solids concentration of 341 milligrams per liter



### Discharge Permit: DP-1934 Kevin's Pro Clean

- County: Eddy | Closest City: Carlsbad
- Applicant: Kevin Shafer, Kevin's Pro Clean, 506 S. Guadalupe, Carlsbad, NM 88220
- NMED Permit Contact: Kambray Townsend, Water Resource Professional, [kambray.townsend@env.nm.gov](mailto:kambray.townsend@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-538-0497 or 505-827-2900.

**Notice:** DP-1934, Kevin's Pro Clean: Kevin Shafer proposes to modify the Discharge Permit for the discharge of up to 9,000 gallons per day of domestic septage and grease processing wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 5230-7 Seven Rivers Highway, approximately 17 miles North of Carlsbad, in Section 31, Township 19 South, Range 26 East, and Section 6, Township 20 South, Range 26 East, Eddy County. Groundwater most likely to be affected is at a depth of approximately 20 feet and had a pre-discharge total dissolved solids concentration of 2,100 milligrams per liter.

### Discharge Permit: DP-1237, Village of Mosquero Wastewater Treatment Plant

- County: Harding | Closest City: Mosquero
- Applicant: Village of Mosquero, Victor R. Vigil, Mayor, P.O. Box 116, Mosquero, NM 87733
- NMED Permit Contact: Andrew Romero, Water Resource Professional, [AndrewC.Romero@env.nm.gov](mailto:AndrewC.Romero@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-660-8624 or 505-827-2900.

**Notice:** DP-1237, Village of Mosquero Wastewater Treatment Plant: Village of Mosquero proposes to renew the Discharge Permit for the discharge of up to 9,900 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at the south end of 5th Street, Mosquero, in Section 22, Township 18 North, Range 28 East, Harding County. Groundwater most likely to be affected is at a depth of approximately 45 to 80 feet and had a pre-discharge total dissolved solids concentration of 280 milligrams per liter.

### Discharge Permit: DP-625, City of Lordsburg Wastewater Treatment Facility

- County: Hidalgo | Closest City: Lordsburg
- Applicant: City of Lordsburg, Glenda F. Greene, Mayor, 409 W Wabash St, Lordsburg, NM 88045
- NMED Permit Contact: Avery Young, Domestic Waste Team Lead, [Avery.Young@env.nm.gov](mailto:Avery.Young@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-699-8564 or 505-827-2900.

**Notice:** DP-625, City of Lordsburg Wastewater Treatment Facility: City of Lordsburg proposes to renew and modify the Discharge Permit for the discharge of up to 500,000 gallons per day of domestic wastewater and up to 25,000 gallons per day of industrial wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds and total dissolved solids. The facility is located at 59 Power Plant Rd, Lordsburg, in Sections 28 and 33, Township 22 South, Range 18 West, Hidalgo County. Groundwater most likely to be affected is at a depth of approximately 4 feet and had a pre-discharge total dissolved solids concentration of 1,779 milligrams per liter.



### Discharge Permit: DP-875, S & H Enterprises, Inc.

- County: Lea | Closest City: Hobbs
- Applicant: Gary M. Schubert, President, P.O. Box 6056, Hobbs, NM 88241
- NMED Permit Contact: Jennifer Fullam, Reuse Team Lead, [Jennifer.Fullam@env.nm.gov](mailto:Jennifer.Fullam@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-670-2496 or 505-827-2900.

**Notice:** DP-875, S & H Enterprises, Inc. proposes to renew the Discharge Permit for the discharge of up to 3.6 million gallons per day of reclaimed domestic wastewater to a cropland application area. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 2826 East Nadine Road, approximately 6 miles south of Hobbs, in Sections 24, 25 and 26, Township 19 south, Range 38 east, and Sections 18, 19, and 30, Township 19 south, Range 39 east, Lea County. Groundwater most likely to be affected is at a depth of approximately 41 feet and had a pre-discharge total dissolved solids concentration of 380 milligrams per liter.

### Discharge Permit: DP-1265, GH Dairy - Turner

- County: Luna | Closest City: Hatch
- Applicant: Gerben Hettinga, Owner, 6939 Schaefer Ave, Suite D Box 301, Chino, CA 91710
- NMED Permit Contact: Aracely Tellez, Water Resource Professional, [Aracely.Tellez@env.nm.gov](mailto:Aracely.Tellez@env.nm.gov) or [acs.general@env.nm.gov](mailto:acs.general@env.nm.gov), Telephone: 505-629-8864 or 505-827-2900.

**Notice:** DP-1265, GH Dairy Turner: Gerben Hettinga proposes to renew the Discharge Permit for closure of a former dairy facility. No discharge will occur under this Discharge Permit, as dairy related operations have ceased. Contaminants of concern included nitrogen compounds. The facility is located approximately 10 miles North of Hatch, in Section 18, Township 20 South, Range 5 West, Luna County. Groundwater most likely to be affected is at a depth of approximately 117 feet and had a pre-discharge total dissolved solids concentration of 336 milligrams per liter.

### Discharge Permit: DP-1772, Pine Springs Camp

- County: Otero | Closest City: Sacramento
- Applicant: Pine Springs Camp, Richard DeVore, Manager, 132 Spring Canyon Rd, Sacramento, NM 88347
- NMED Permit Contact: Avery Young, Domestic Waste Team Lead, [Avery.Young@env.nm.gov](mailto:Avery.Young@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-699-8564 or 505-827-2900.

**Notice:** DP-1772, Pine Springs Camp proposes to renew the Discharge Permit for the discharge of up to 9,950 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 132 Spring Canyon Rd, Sacramento, in Section 32, Township 17 South, Range 13 East, Otero County. Groundwater most likely to be affected is at a depth of approximately 49 feet and had a pre-discharge total dissolved solids concentration of 324 milligrams per liter.



### Discharge Permit: DP-1969, Village of Cloudcroft Wastewater Treatment Facility

- County: Otero | Closest City: Cloudcroft
- Applicant: Village of Cloudcroft, William Denney, Mayor, P.O. Box 317, Cloudcroft, NM 88317
- NMED Permit Contact: Avery Young, Domestic Waste Team Lead, [Avery.Young@env.nm.gov](mailto:Avery.Young@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-699-8564 or 505-827-2900.

**Notice:** DP-1969, Village of Cloudcroft Wastewater Treatment Facility: Village of Cloudcroft proposes the Discharge Permit for the discharge of up to 300,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 1560 James Canyon Hwy 82, Cloudcroft, in Section 35, Township 15 South, Range 12 East, County. Groundwater most likely to be affected is at a depth of approximately 50 feet and had a pre-discharge total dissolved solids concentration of 450 milligrams per liter.

### Discharge Permit: DP-898, Bonestroo and Sons Dairies, LLC

- County: Roosevelt | Closest City: Portales
- Applicant: Gary Bonestroo, 326-B NM 467, Portales, NM 88130
- NMED Permit Contact: Keelyn Taylor, Water Resources Professional, [keelynl.taylor@env.nm.gov](mailto:keelynl.taylor@env.nm.gov) or [acs.general@env.nm.gov](mailto:acs.general@env.nm.gov), Telephone: 505-469-4764 or 505-827-2900

**Notice:** DP-898, Bonestroo and Sons Dairies, LLC: Gary Bonestroo proposes to renew and modify the Discharge Permit for the discharge of up to 9,999 gallons per day of wastewater from the production area of a dairy facility. Potential contaminants from this type of discharge include nitrogen compounds. The facility and discharge locations are located at 326-B NM 467, Portales, approximately 7 miles North of Portales, in Section(s) 1, 2, and 6, Township 1 South, Range 34 East, Roosevelt. Groundwater most likely to be affected is at a depth of approximately 66 feet and had a pre-discharge total dissolved solids concentration of 420 milligrams per liter.

### Discharge Permit: DP-1357, Blue Haven Youth Camp, Inc.

- County: San Miguel | Closest City: Las Vegas
- Applicant: Camp Blue Haven LLC, Jarrod Lucero, Caretaker, 62 Camp South St, Las Vegas, NM 87701
- NMED Permit Contact: Lochlin Farrell, Geoscientist, [Lochlin.Farrell@env.nm.gov](mailto:Lochlin.Farrell@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: (505) 660-8061 or 505-827-2900.

**Notice:** DP-1357, Blue Haven Youth Camp, Inc.: Camp Blue Haven LLC proposes to renew the Discharge Permit for the discharge of up to 8,600 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 62 Camp South St, approximately 12 miles west of Las Vegas, in Section 11, Township 16 North, Range 14 East, San Miguel County. Groundwater most likely to be affected is at a depth of approximately 150 feet and had a pre-discharge total dissolved solids concentration of 658 milligrams per liter.



### Discharge Permit: DP-1871, San Ysidro Waste Site

- County: Sandoval | Closest City: San Ysidro
- Applicant: Shawn Benavidez, Owner, P.O. Box 45983, Rio Rancho, NM 87174
- NMED Permit Contact: Gerald Knutson, Water Resource Professional, [Gerald.Knutson@env.nm.gov](mailto:Gerald.Knutson@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: 505-660-7189 or 505-827-2900.

**Notice:** DP-1871, San Ysidro Waste Site: Shawn Benavidez proposes to renew and modify the Discharge Permit for the discharge of up to 9,999 gallons per day of domestic septage and food-related grease trap/interceptor waste to a disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 38 Sandia Drive, approximately 1 mile southwest of San Ysidro, in Section 12, Township 15 north, Range 01 east, Sandoval County. Groundwater most likely to be affected is at a depth of approximately 80 feet and had a pre-discharge total dissolved solids concentration of 1,400 milligrams per liter.

### Discharge Permit: DP-1145, El Rancho Mobile Home Park

- County: Taos | Closest City: Taos
- Applicant: Faustin Gonzales, P.O. Box 1050, El Prado, NM 87529
- NMED Permit Contact: Lochlin Farrell, Geoscientist, [Lochlin.Farrell@env.nm.gov](mailto:Lochlin.Farrell@env.nm.gov) or [pps.general@env.nm.gov](mailto:pps.general@env.nm.gov), Telephone: (505) 660-8061 or 505-827-2900.

**Notice:** DP-1145, El Rancho Mobile Home Park: Faustin Gonzales proposes to renew the Discharge Permit for the discharge of up to 6,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 24862 US Highway 64, approximately three miles west of Taos, in Sections 26 (projected), Township 26 North, Range 12 East, Taos County. Groundwater most likely to be affected is at a depth of approximately 210 feet and had a pre-discharge total dissolved solids concentration of 200 milligrams per liter.

END OF PUBLIC NOTICE