

OCT 24 2018

BUREAU

in U



MANIFEST ID

HAULED LIQUID WASTE DISCHARGE MANIFEST

1. LIQUID WASTE STREAM IDENTIFICATION

A.) Volume: 1000 gallons B.) Holding Tank _____
 Septic Tank xxxxxxx
 Chemical _____

C.) Source: _____

*Description of other & Special handling instructions, if any: _____

2. GENERATOR OF LIQUID WASTE

A.) Complete Name (print or type): Mark Ray
 B.) Phone Number : _____
 C.) Complete Pickup Address: El Valle Escondido

The undersigned being duly authorized does hereby certify to the accuracy of the source & type of hauled liquid waste identified above & subject to this manifest.

DATE: 9/27/18 CUSTOMER SIGNATURE: _____

3. HAULER OF LIQUID WASTE

A.) Company Name: S&R SEPTIC SERVICE B.) Discharge Permit #: DP-465
 C.) 1. Pump out Date: 9/27/18
 2. Type of Alkaline Material used : LIME
 3. Amount (Pounds) : 50 lbs per truckload
 4. How Mixed : Slurry mixed and pumped into truck
 5. Initial pH : 12.7
 6. pH after 30 min : 12.4

"I certify, under penalty of law, that the prescribed ground water protection, vector attraction reduction and pathogen reduction requirements have been met. This determination has been made under my direction and supervision in accordance with the prescribed procedures. I am aware that there are significant penalties for false certification including the possibility of fines and imprisonment."

DATE: 9/27/18 SIGNATURE: Steve Rael



S&R PLUMBING
 Steve E. or Loretta A. Rael
 P.O. Box 3155
 Ranchos de Taos, New Mexico 87557
 575-758-3515

MANIFEST ID _____

HAULED LIQUID WASTE DISCHARGE MANIFEST

1. LIQUID WASTE STREAM IDENTIFICATION

A.) Volume : 1000 gallons B.) Holding Tank _____
 Septic Tank xxxxxxx
 Chemical _____
 C.) Source : _____

*Description of other & Special handling instructions, if any: _____

2. GENERATOR OF LIQUID WASTE

A.) Complete Name (print or type): Phoenix Mechanical
 B.) Phone Number : Wesley Souterston 758-3072
 C.) Complete Pickup Address: Jess NM 87571

The undersigned being duly authorized does hereby certify to the accuracy of the source & type of hauled liquid waste identified above & subject to this manifest.

DATE: 9/29/18 CUSTOMER SIGNATURE: _____

3. HAULER OF LIQUID WASTE

A.) Company Name: S&R SEPTIC SERVICE B.) Discharge Permit #: DP-465
 C.) 1. Pump out Date: 9/29/18
 2. Type of Alkaline Material used : LIME
 3. Amount (Pounds) : 100 lbs per truckload
 4. How Mixed : Slurry mixed and pumped into truck
 5. Initial pH : 12.6
 6. pH after 30 min : 12.4

"I certify, under penalty of law, that the prescribed ground water protection, vector attraction reduction and pathogen reduction requirements have been met. This determination has been made under my direction and supervision in accordance with the prescribed procedures. I am aware that there are significant penalties for false certification including the possibility of fines and imprisonment."

DATE: 9/29/18 SIGNATURE: Steve Rael



S&R PLUMBING
 Steve E. or Loretta A. Rael
 P.O. Box 3155
 Ranchos de Taos, New Mexico 87557
 575-758-3515

MANIFEST ID _____

HAULED LIQUID WASTE DISCHARGE MANIFEST

1. LIQUID WASTE STREAM IDENTIFICATION

A.) Volume: 1000 gallons
 B.) Holding Tank _____
 Septic Tank xxxxxxx
 Chemical _____
 C.) Source: _____

*Description of other & Special handling instructions, if any: _____

2. GENERATOR OF LIQUID WASTE

A.) Complete Name (print or type): Elizabeth Woodberry
 B.) Phone Number: 505-440-3471
 C.) Complete Pickup Address: 630 Jose Francisco

The undersigned being duly authorized does hereby certify to the accuracy of the source & type of hauled liquid waste identified above & subject to this manifest.

DATE: 9/29/18 CUSTOMER SIGNATURE: _____

3. HAULER OF LIQUID WASTE

A.) Company Name: S&R SEPTIC SERVICE B.) Discharge Permit #: DP-465

C.) 1. Pump out Date: 9-29-18
 2. Type of Alkaline Material used: LIME
 3. Amount (Pounds): 100 lbs per truck load
 4. How Mixed: Slurry mixed and pumped into truck
 5. Initial pH: 12.5
 6. pH after 30 min: 12.3

"I certify, under penalty of law, that the prescribed ground water protection, vector attraction reduction and pathogen reduction requirements have been met. This determination has been made under my direction and supervision in accordance with the prescribed procedures. I am aware that there are significant penalties for false certification including the possibility of fines and imprisonment."

DATE: 9/29/18 SIGNATURE: Steve Rael