



CERTIFIED MAIL – RETURN RECEIPT REQUESTED

July 22, 2026

Juan Carlos Crosby, Executive Director
Camino Real Regional Utility Authority
P.O. Box 429
Sunland Park, New Mexico 88063

RE: Draft Discharge Permit Renewal, DP-1281, West Mesa / Santa Teresa Wastewater Treatment Facility

Dear Juan Carlos Crosby:

The New Mexico Environment Department (NMED) hereby provides notice to you of the proposed approval of Ground Water Discharge Permit Renewal, DP-1281, (copy enclosed), pursuant to Subsection H of 20.6.2.3108 NMAC. NMED will publish notice of the availability of the draft Discharge Permit in the near future for public review and comment and will forward a copy of that notice to you.

Prior to making a final ruling on the proposed Discharge Permit, NMED will allow 30 days from the date the public notice is published in the newspaper for any interested party, including the Discharge Permit applicant, i.e., yourself, to submit written comments and/or request a public hearing. A hearing request shall set forth the reasons why a hearing is requested. NMED will hold a hearing in response to a timely hearing request if the NMED Secretary determines there is substantial public interest in the proposed Discharge Permit.

Please review the enclosed draft Discharge Permit carefully. Please be aware that this Discharge Permit may contain conditions that require the permittee to implement operational, monitoring, or closure actions by a specified deadline.

Please submit written comments or a request for hearing to my attention at the address below, via email to haylea.nisbet@env.nm.gov or to pps.general@env.nm.gov, or directly into the NMED Public Comment Portal at <https://nmed.commentinput.com/comment/search>. If NMED does not receive written comments or a request for hearing during the public comment period, the draft Discharge Permit will become final.

Juan Carlos Crosby
July 22, 2026
Page 2 of 2

Thank you for your cooperation during the review process. Feel free to contact me with any questions at (505) 795-2831.

Sincerely,

Haylea Nisbet
Digitally signed by Haylea
Nisbet
Date: 2026.07.22 16:24:02
-06'00'

Haylea Nisbet, Acting Large System Domestic Waste Team Leader

enc: Draft Discharge Permit Renewal, DP-1281

cc: Eric Lopez, Bridel Consultant, bfacilityops@comcast.net
Raul Rangel, Wastewater Operator, raul.rangel@sunlandpark-nm.gov
Mireya Rascon, Doña Ana County, mireyar@donaana.gov



NEW MEXICO
ENVIRONMENT DEPARTMENT
Ground Water Quality Bureau
1190 Saint Francis Drive / PO Box 5469
Santa Fe, NM 87502-5469
Phone (505) 827-2900 Fax (505) 827-2965
www.env.nm.gov



Draft: July 22, 2026

GROUND WATER QUALITY BUREAU
DISCHARGE PERMIT
Issued under 20.6.2 NMAC

Facility Name: West Mesa / Santa Teresa Wastewater Treatment Facility
Discharge Permit Number: DP-1281
Facility Location: 4770 Pete Dominici Highway
Approximately 2.5 miles southwest of Santa Teresa, NM

County: Doña Ana

Permittee: Juan Carlos Crosby, Executive Director
Mailing Address: Camino Real Regional Utility Authority
P.O. Box 429
Sunland Park, New Mexico 88063

Facility Contact: Eric Lopez, Bridel Consultant
Telephone Number/Email: (575) 652-4711 / bfacilityops@comcast.net

Permitting Action: Renewal
Permit Issuance Date: DATE
Permit Expiration Date: DATE

NMED Permit Contact: Haylea Nisbet
Telephone Number/Email: (505) 795-2831 / haylea.nisbet@env.nm.gov or
(505) 827-2900 / pps.general@env.nm.gov

JUSTIN D. BALL
Chief, Ground Water Quality Bureau
New Mexico Environment Department

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	FINDINGS	3
III.	AUTHORIZATION TO DISCHARGE	3
IV.	CONDITIONS	3
A.	OPERATIONAL PLAN	3
	Operational Actions with Implementation Deadlines	4
	Operating Conditions	5
B.	MONITORING AND REPORTING	11
	Due Dates for Monitoring Reports	11
	Facility Monitoring Conditions	12
C.	CONTINGENCY PLAN	20
D.	CLOSURE PLAN	27
	Permanent Facility Closure Conditions	27
E.	GENERAL TERMS AND CONDITIONS	29

ATTACHMENTS

Discharge Permit Summary
Groundwater Discharge Permit Guidance for Synthetically Lined Lagoons – Liner
Material and Site Preparation, Revision 0.0, May 2007
New Mexico Environment Department Ground Water Quality Bureau Monitoring Well
Construction and Abandonment Guidelines, Revision 1.1, March 2011 (Monitoring
Well Guidance)
New Mexico Environment Department – Ground Water Quality Bureau Guidance: How
to Sample a Monitoring Well
Groundwater Monitoring Worksheet and Reference Chart
Land Application Data Sheet (LADS - <https://www.env.nm.gov/forms/>)

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this groundwater discharge permit Renewal (Discharge Permit or DP-1281) to the Camino Real Regional Utility Authority (Permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Ground and Surface Water Protection Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from West Mesa / Santa Teresa Wastewater Treatment Facility (Facility) in order to protect groundwater and those segments of surface water gaining from groundwater inflow for present and potential future use as domestic and agricultural water supply and other uses, and to protect public health. It is NMED's determination in issuing this Discharge Permit that the Permittee has met the requirements of Subsection C of 20.6.2.3109 NMAC. The Permittee is responsible for complying with the terms and conditions of this Discharge Permit pursuant to Section 20.6.2.3104 NMAC; failure to do so may result in enforcement action by NMED (20.6.2.1220 NMAC).

Described below are the activities that produce the discharge, the location of the discharge, and the quantity, quality, and flow characteristics.

The Facility receives and treats up to 600,000 gallons per day (gpd) of domestic and industrial wastewater using a Wastewater Treatment Facility (WWTF). Treated wastewater is stored in two synthetically lined effluent storage impoundments and then discharges to three effluent disposal areas; Effluent Disposal Area 1 (11.2-acres), Effluent Disposal Area 2 (11.5-acres), and Effluent Disposal Area 3 (26-acres). The Facility discharges treated wastewater to a leach field on an emergency basis.

Discharge Permit Location Information:

Physical Address	4770 Pete Domenici Highway
Nearest Town/City	Approximately 2.5 miles southwest of Santa Teresa
Section, Township, Range	Section 30, Township 28 South, Range 03 East
County	Doña Ana
Depth to Groundwater	315 feet
Pre-Discharge TDS	500 to 1000 mg/L

Discharge Permit Issuance History:

Original Permit Issuance	July 25, 2000
Permit Renewal	January 3, 2009
Permit Renewal	April 14, 2014
Permit Modification	June 16, 2017
Permit Renewal	May 29, 2019

The application (i.e., discharge plan) associated with this Discharge Permit consists of the materials submitted by the Permittee dated June 5, 2024, and materials contained in the administrative record prior to issuance of this Discharge Permit.

The Permittee shall manage the discharge in accordance with all conditions and requirements of this Discharge Permit.

NMED reserves the right to require a Discharge Permit modification in the event NMED determines that the Permittee is or may be violating, or is likely to violate in the future, the requirements of 20.6.2 NMAC or the standards of Section 20.6.2.3103 NMAC. NMED reserves this right pursuant to Section 20.6.2.3109 NMAC. An NMED requirement to modify the Discharge Permit may result from a determination by the department that structural controls and/or management practices approved under this Discharge Permit are insufficiently protective of groundwater quality and human health. NMED reserves the right to require the Permittee to implement abatement of water pollution and remediate groundwater quality.

NMED issuance of this Discharge Permit does not relieve the Permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

This Discharge Permit may use the following acronyms and abbreviations.

Abbreviation	Explanation	Abbreviation	Explanation
BOD ₅	biochemical oxygen demand (5-day)	NMED	New Mexico Environment Department
CAP	Corrective Action Plan	NMSA	New Mexico Statutes Annotated
CFR	Code of Federal Regulations	NO ₃ -N	nitrate-nitrogen
CFU	colony forming unit	NTU	nephelometric turbidity units
Cl	chloride	QA/QC	Quality Assurance/Quality Control
EPA	United States Environmental Protection Agency	TDS	total dissolved solids
gpd	gallons per day	TKN	total Kjeldahl nitrogen
LAA	land application area	total nitrogen	= TKN + NO ₃ -N
LADS	Land Application Data Sheet(s)	TRC	total residual chlorine
mg/L	milligrams per liter	TSS	total suspended solids
mL	milliliters	WQA	New Mexico Water Quality Act
MPN	most probable number	WQCC	Water Quality Control Commission
NMAC	New Mexico Administrative Code	WWTF	Wastewater Treatment Facility

II. FINDINGS

In issuing this Discharge Permit, NMED finds the following.

1. The Permittee is discharging effluent or leachate from the Facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing concentration of 10,000 mg/L or less of TDS, within the meaning of Subsection A of 20.6.2.3101 NMAC, without exceeding standards of 20.6.2.3103 NMAC for any water contaminant.
2. The Permittee is discharging effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit and Sections 20.6.2.3000 through 20.6.2.3114 NMAC.
3. The discharge from this Facility has the potential to contain water contaminants or toxic pollutants elevated above the standards of Section 20.6.2.3103 NMAC and is not subject to the exemption at Subsection 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

The Permittee is responsible for ensuring that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein pursuant to 20.6.2.3104 NMAC.

This Discharge Permit authorizes the Permittee to discharge up to 600,000 gpd of domestic/industrial wastewater. This Discharge Permit authorizes the Permittee to store treated wastewater in two synthetically lined effluent storage impoundments and then discharge to three effluent disposal areas totaling 48.7 acres. This Discharge Permit also authorizes the Permittee to discharge up to 50,000 gpd of treated wastewater to a leach field on an emergency basis.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection D of 20.6.2.3109 NMAC]

IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

A. OPERATIONAL PLAN

#	Terms and Conditions
1.	The Permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 2 and 4 NMAC. [Subsection C of 20.6.2.3109 NMAC]
2.	The Permittee shall operate in a manner that does not violate standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC. [20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]

Operational Actions with Implementation Deadlines

#	Terms and Conditions
3.	Within 90 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall install fencing around the effluent disposal areas to control access by the general public and animals. The fencing shall consist of a minimum of four-strand barbed wire fencing and locking gates. Documentation of fence installation shall consist of a narrative statement describing the fences and gates and date-stamped photographs. The Permittee shall submit the documentation to NMED in the next required periodic monitoring report. [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]
4.	Within 30 days of the installation of the effluent disposal area fences, the Permittee shall post the following signs at the following locations: Signs posted every 500 feet along the disposal area fences that state: "Notice: Waste Disposal Area - KEEP OUT" and "Aviso: Área de Disposición - NO ENTRAR". All signs shall be weatherproof and remain legible for the term of this Discharge Permit. The Permittee shall submit documentation demonstrating sign installation that consists of date stamped photographs to NMED in the next required periodic monitoring report. [NMSA 1978, § 74-6-5.D, Subsections B and C of 20.6.2.3109 NMAC]
5.	Within 90 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall repair or replace the spray irrigation systems for the effluent disposal areas to assure the discharge of treated wastewater occurs evenly throughout the entire disposal areas. Documentation of the spray irrigation system repairs shall consist of a narrative statement describing the actions taken and date-stamped photographs.

#	Terms and Conditions
	The Permittee shall submit the documentation to NMED in the next required periodic monitoring report. [Subsection A of 20.6.2.3107 NMAC, Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]
6.	Within 180 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall measure the thickness of the settled solids in the two effluent storage impoundments. The Permittee shall report the results of the solids thickness measurements to NMED in the next required periodic monitoring report. The Permittee shall measure the thickness of settled solids in accordance with the following procedure. - Divide the total surface area of the treatment impoundment into nine equal sub-areas. - Obtain one measurement (to the nearest half foot) using a settled solids measurement device (e.g., core sampler) per sub-area. - Calculate the average of the nine measurements. In the event that the measured settled solids exceed one-third of the maximum liquid depth in the impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]

Operating Conditions

#	Terms and Conditions			
7.	The Permittee shall ensure that treated wastewater discharged after the disinfection unit does not exceed the following discharge limit. Total Nitrogen: 15 mg/L [Subsection C of 20.6.2.3109 NMAC]			
8.	The Permittee shall ensure that treated wastewater discharged from after the disinfection unit does not exceed the following discharge limits. <table><tr><td>Test</td><td>30-day Average</td><td>Maximum</td></tr></table>	Test	30-day Average	Maximum
Test	30-day Average	Maximum		

#	Terms and Conditions												
	<table><tr><td>Fecal Coliform</td><td>1,000 CFU or MPN/100 mL</td><td>5,000 CFU or MPN/100 mL</td></tr><tr><td>OR</td><td>OR</td><td>OR</td></tr><tr><td>E. coli bacteria</td><td>630 CFU or MPN/100 mL</td><td>3,150 CFU or MPN/100 mL</td></tr><tr><td>TRC</td><td>Monitor Only</td><td>Monitor Only</td></tr></table> [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]	Fecal Coliform	1,000 CFU or MPN/100 mL	5,000 CFU or MPN/100 mL	OR	OR	OR	E. coli bacteria	630 CFU or MPN/100 mL	3,150 CFU or MPN/100 mL	TRC	Monitor Only	Monitor Only
Fecal Coliform	1,000 CFU or MPN/100 mL	5,000 CFU or MPN/100 mL											
OR	OR	OR											
E. coli bacteria	630 CFU or MPN/100 mL	3,150 CFU or MPN/100 mL											
TRC	Monitor Only	Monitor Only											
9.	The Permittee shall apply treated wastewater evenly throughout the three effluent disposal areas such that the amount of total nitrogen applied does not exceed 200 pounds per acre in any rolling 12-month period. The Permittee shall not adjust nitrogen content to account for volatilization or mineralization processes. The Permittee shall prevent excessive ponding from occurring due to the discharge. [Subsection C of 20.6.2.3109 NMAC]												
10.	The Permittee shall ensure adherence to the following general requirements for disposal of treated wastewater. a) The Permittee shall install and maintain signs in English and Spanish at all disposal areas such that they are visible and legible for the term of this Discharge Permit. The Permittee shall post signs at the entrance to disposal areas and at other locations where public exposure to treated wastewater may occur. The signs shall state: "Notice: Waste Disposal Area - KEEP OUT" and "Aviso: Área de Disposición - NO ENTRAR". The Permittee may submit alternate wording and/or graphics to NMED for approval. b) Treated wastewater systems shall have no direct or indirect cross connections with public water systems or irrigation wells pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC). c) Above-ground use of treated wastewater shall not result in excessive ponding of wastewater. The Permittee shall not discharge treated wastewater at times when the disposal area is saturated or frozen. d) The Permittee shall confine discharge of treated wastewater to the disposal area. e) The Permittee shall not discharge treated wastewater to crops used for human consumption. f) Water supply wells within 200 feet of a disposal area shall have adequate wellhead construction pursuant to 19.27.4 NMAC. g) Valves, outlets, and sprinkler heads used in treated wastewater systems shall be accessible only to authorized personnel.												

#	Terms and Conditions
	The Permittee shall demonstrate adherence to these requirements by submitting documentation consisting of narrative statements and date-stamped photographs as appropriate. The Permittee shall submit the documentation to NMED once during the term of this Discharge Permit in the next required periodic monitoring report after the issuance of the Discharge Permit. [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1–78, § 74-6–5.D]
11.	The Permittee shall meet the following setbacks, access restrictions and equipment requirements for spray irrigation using treated wastewater. a) Maintain a minimum 500-foot setback between any dwellings or occupied establishments and the edge of the disposal area. b) Postpone irrigation using treated wastewater at times when windy conditions may result in drift of treated wastewater outside of the disposal area. c) Restrict access to the disposal area using a perimeter fencing with, at minimum, four-strand barbed wire and a locking gate, or other access controls approved by NMED. d) Prohibit public access during times when treated wastewater is being applied to the disposal area. e) Limit the spray irrigation system to low trajectory spray nozzles. f) Prohibit the irrigation of fodder, fiber and seed crops for milk producing animals with treated wastewater. g) Disposal is not approved for growing crops, grazing, or harvestable product. [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1–78, § 74-6-5.D]
12.	The Permittee shall institute a backflow prevention method to protect wells and public water supply systems from contamination by treated wastewater prior to discharging to the disposal area. Backflow prevention shall be achieved by a total disconnect (physical air gap separation between the discharge pipe and the liquid surface at least twice the diameter of the discharge pipe), or by a reduced pressure principal backflow prevention assembly (RP) installed on the line between the fresh water supply wells or public water supply and the treated wastewater delivery system. The Permittee shall maintain backflow prevention at all times. The Permittee shall have RP devices inspected and tested by a certified backflow prevention assembly tester at the time of installation, repair or relocation and at least on an annual basis thereafter. The backflow prevention assembly tester shall have successfully completed a 40-hour backflow prevention course based on the University of Southern California’s Backflow Prevention Standards and Test Procedures, and obtained certification demonstrating completion. The Permittee shall have all malfunctioning RP devices repaired or replaced within 30 days of discovery. The

#	Terms and Conditions
	Permittee shall cease using supply lines associated with the RP device until repair or replacement is complete. The Permittee shall maintain copies of the inspection and maintenance records and test results for each RP device associated with the backflow prevention program at a location available for inspection by NMED. [Subsection C of 20.6.2.3109 NMAC]
13.	The Permittee shall maintain fences around the Facility to restrict access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. The Permittee shall maintain the fences to serve the stated purpose throughout the term of this Discharge Permit. [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]
14.	The Permittee shall maintain signs indicating that the wastewater at the Facility is not potable. The Permittee shall post signs at the Facility entrance and other areas where there is potential for public contact with wastewater. The Permittee shall print signs in English and Spanish and shall ensure the signs remain visible and legible for the term of this Discharge Permit. [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]
15.	The Permittee shall maintain the impoundment liners to avoid conditions that could affect the liner or the structural integrity of the impoundments. Characterization of such conditions may include the following: • erosion damage; • animal burrows or other damage; • the presence of vegetation including aquatic plants, weeds, woody shrubs, or trees growing within five feet of the top inside edge of a sub-grade impoundment, within five feet of the toe of the outside berm of an above-grade impoundment, or within the impoundment itself; • the presence of large debris or large quantities of debris in the impoundment; • evidence of seepage; or • evidence of berm subsidence. The Permittee shall routinely control vegetation growing around the impoundments by mechanical removal that is protective of the impoundment liner. The Permittee shall visually inspect the impoundments and surrounding berms on a monthly basis to ensure proper maintenance. In the event that an inspection reveals

#	Terms and Conditions
	any evidence of damage that threatens the structural integrity of an impoundment berm or liner, or that may result in an unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit. The Permittee shall create and maintain a log of all impoundment inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
16.	The Permittee shall preserve a minimum of two feet of freeboard, i.e., the distance between the highest calculated liquid level in the impoundments and the liquid level which would result in the release of stored liquid from the impoundments. In the event that the Permittee determines that it cannot preserve two feet of freeboard in the impoundments, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
17.	The Permittee shall maintain the sludge drying beds to avoid conditions that could affect the structural integrity. Characterization of such conditions may include the following; • erosion damage; • animal burrows or other damage; • the presence of vegetation including weeds, woody shrubs or trees growing in or around the drying beds; • the presence of large debris or large quantities of debris in or around the sludge drying beds; • evidence of seepage; • cracking and faults in or around the sludge drying beds. The Permittee shall not exceed the physical or design capacity for each of the sludge drying beds. The permittee shall control vegetation growing around the sludge drying beds by mechanical removal that is protective of the sludge drying beds. The Permittee shall visually inspect the sludge drying beds on a monthly basis to ensure proper maintenance. In the event that inspection reveals any evidence of damage that threatens the structural integrity of the sludge drying beds, or that may result in an

#	Terms and Conditions
	unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit. The Permittee shall create and maintain a log of all sludge drying bed inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall provide the log to NMED upon request. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
18.	The Permittee shall visually inspect the area above the emergency leachfield (emergency disposal system) monthly to ensure proper maintenance. The Permittee shall correct any conditions that indicate damage to the disposal system. The Permittee shall ensure conditions corrected include erosion damage, animal activity/damage, woody shrubs, evidence of seepage, or any other condition indicating damage. The Permittee shall keep a log of the inspections that includes a date of the inspection, any findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request. In the event of a failure of the emergency disposal system, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit. [Subsections A and D of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
19.	The Permittee shall properly manage all solids generated by the treatment system to maintain effective operation of the system by removing solids as necessary and in accordance with associated equipment manufacturer's specifications. The Permittee shall contain, transport, and dispose of all solids removed from the treatment process in accordance with all local, state, and federal regulations. The Permittee shall maintain manifests for all solids transported from the treatment Facility for off-site disposal. The manifests shall identify the name of the hauler, the date of off-site shipment, the volume of solids removed, the disposal method, and disposal location. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
20.	The Permittee shall inspect and clean the lift station as needed to prevent pump failure. The Permittee shall maintain a record of lift station inspections, repairs, and cleanings. The Permittee shall make the record available to NMED upon request.

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
21.	The Permittee shall utilize operators, certified by the State of New Mexico at the appropriate level pursuant to 20.7.4 NMAC, to operate the wastewater collection, treatment, and disposal systems. A certified operator or a direct supervisee of a certified operator shall perform the operations and maintenance of all or any part of the wastewater system. The Permittee shall notify the NMED within 24 hours if at any time the Permittee no longer has a certified operator maintaining the system. [Subsection C of 20.6.2.3109 NMAC, 20.7.4 NMAC]

B. MONITORING AND REPORTING

#	Terms and Conditions
22.	The Permittee shall conduct the monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
23.	METHODOLOGY - Unless otherwise specified by this Discharge Permit, or approved in writing by NMED, the Permittee shall use sampling and analytical techniques that conform with the references listed in Subsection B of 20.6.2.3107 NMAC. [Subsection B of 20.6.2.3107 NMAC]

Due Dates for Monitoring Reports

#	Terms and Conditions
24.	Quarterly monitoring - The Permittee shall perform monitoring and other Permit required actions during the following periods and shall submit quarterly reports to NMED by the following due dates: • January 1st through March 31st – due by May 1st; • April 1st through June 30th – due by August 1st; • July 1st through September 30th – due by November 1st; and • October 1st through December 31st – due by February 1st.

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC]

Monitoring Actions with Implementation Deadlines

#	Terms and Conditions
25.	Within 90 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall submit a written groundwater monitoring well location proposal for NMED review and approval. The proposal shall designate the installation locations of the monitoring well required by this Discharge Permit. The proposal shall include, at a minimum, the following information. a) A map showing the proposed location of the monitoring well in relation to the boundary of the source it is intended to monitor. b) A written description of the specific location proposed for the monitoring well including the distance (in feet) and direction of the monitoring well from the edge of the source it is intended to monitor and the latitude and longitude coordinates for each well in decimal format. Examples include: 35 feet north-northwest of the northern berm of the synthetically lined impoundment and 35.898306 and -107.281519; 45 feet due south of the leach field and 35.898306 and -107.281519; and 30 feet southeast of the reuse area and 35.898306 and -107.281519. c) A statement describing the groundwater flow direction beneath the Facility, and documentation and/or data supporting the determination. The Permittee must have NMED's approval of all monitoring well locations prior to their installation. [Subsection A of 20.6.2.3107 NMAC]
26.	Within 150 days of the issuance date of this Discharge Permit (by DATE), the Permittee shall install the following new monitoring well. a) One monitoring well (MW-1) located hydrologically downgradient of the three effluent disposal areas. The Permittee shall complete the well in accordance with the attached Monitoring Well Guidance. The Permittee shall affix a permanent label with the well identification number above. Unless otherwise noted in this Discharge Permit, the requirement to install a monitoring well downgradient of a source is <u>not</u> contingent upon construction of the Facility, or discharge of wastewater from the Facility.

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC]
27.	Following the installation of the monitoring well required by this Discharge Permit, the Permittee shall sample groundwater in the well and analyze the samples for TKN, NO₃-N, TDS, and Cl. The Permittee shall perform groundwater sample collection, preservation, transport, and analysis according to the following procedure. - Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot. - Purge three well volumes of water from the well prior to sample collection using the attached Purge Chart. - Obtain samples from the well for analysis. - Properly prepare, preserve, and transport samples. - Analyze samples in accordance with the methods authorized in this Discharge Permit. Within 45 days of the installation of the monitoring well the Permittee shall submit a well completion report to NMED. A well completion report shall at a minimum include: the Office of the State Engineer permit, well construction and lithologic logs, latitude and longitude coordinates for each well in decimal format, depth-to-most-shallow groundwater measurements, analytical results including the laboratory QA/QC summary report, and a facility layout map showing the location and number of each well. The Permittee shall ensure the well completion report addresses each numbered item in the General Drilling and Well Specifications in the attached Monitoring Well Guidelines. [Subsection A of 20.6.2.3107 NMAC]
28.	Within 210 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall perform a professional survey of all groundwater monitoring wells approved by NMED for Discharge Permit monitoring purposes. The survey shall be tied or referenced to a U.S. Geological Survey (USGS) or other permanent benchmark. Survey data shall include northing, easting and elevation to the nearest one-hundredth of a foot or shall be in accordance with the “Minimum Standards for Surveying in New Mexico” (12.8.2 NMAC). The survey shall bear the seal and signature of a licensed New Mexico professional surveyor (pursuant to the New Mexico Engineering and Surveying Practice Act and the rules promulgated under that authority). The Permittee shall utilize the survey to establish an elevation at the top-of-casing, with a permanent marking indicating the point of elevation.

#	Terms and Conditions
	The Permittee shall measure the depth-to-most-shallow groundwater to the nearest one-hundredth of a foot in all surveyed wells and referenced to mean sea level, and the data shall be used to develop a groundwater elevation contour, i.e., potentiometric surface, map showing the location of all monitoring wells and the direction and gradient of groundwater flow in the uppermost aquifer below the Facility. The Permittee shall submit the survey data to NMED within 30 days of survey completion. [Subsection A of 20.6.2.3107 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]
29.	The Permittee shall sample treated wastewater for the presence of perfluorinated chemicals (PFCs). Within 180 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall collect a single grab sample after the disinfection unit that is representative of the discharge contained therein. The Permittee shall analyze the sample for the following PFCs: • perfluorohexane sulfonic acid (PFHxS) (CAS 355-46-4) • perfluorooctane sulfonate (PFOS) (CAS 1763-23-1) • perfluorooctanoic acid (PFOA) (CAS 335-67-1) The Permittee shall properly collect, prepare, preserve, transport, and analyze the sample in accordance with EPA Method 1633, or an equivalent method that uses liquid chromatography and tandem mass spectrometry (LC/MS/MS). The reporting limit shall be low enough to identify whether the combined concentration of the perfluorinated chemicals is less than the Tap Water Screening Level identified in the <i>NMED Risk Assessment Guidance for Site Assessments and Investigations</i>, Table A-1 available on the NMED Hazardous Waste Bureau's website under Guidance Documents. The Permittee shall take appropriate measures to avoid cross-contamination while collecting and transporting the sample. The selected laboratory should be able to provide guidance that ensures sample integrity. The Permittee shall submit a copy of the laboratory report, including analytical results, the QA/QC summary, and the Chain of Custody to NMED within 30 days of laboratory report receipt. [Subsection H of 20.6.2.3109 NMAC, Subsection A of 20.6.2.3107 NMAC]

Groundwater Monitoring Conditions

#	Terms and Conditions
30.	The Permittee shall perform quarterly groundwater sampling in the following groundwater monitoring wells and analyze the samples for TKN, NO₃-N, TDS, and Cl. b) MW-1, to be located hydrologically downgradient of the three effluent disposal areas. The Permittee shall perform groundwater sample collection, preservation, transport, and analysis according to the following procedures. a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot. b) Purge three well volumes of water from the well prior to sample collection. c) Obtain samples from the well for analysis. d) Properly prepare, preserve, and transport samples. e) Analyze samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the depth-to-most-shallow groundwater measurements and the laboratory analytical data results including the laboratory QA/QC summary report and Chain of Custody for each well to NMED in the quarterly monitoring reports. [Subsection A of 20.6.2.3107 NMAC]
31.	NMED shall have the option to perform downhole inspections of all groundwater monitoring wells identified in this Discharge Permit. NMED shall establish the inspection date and notify the Permittee. The Permittee shall remove any existing dedicated pumps at least 48 hours prior to NMED inspection to allow adequate settling time of sediment agitated from pump removal. Should the Permittee decide to install a pump in a monitoring well without a dedicated pump, the Permittee shall notify NMED at least 90 days prior to pump installation so that NMED can schedule a downhole well inspection prior to pump placement. [Subsections A and D of 20.6.2.3107 NMAC]

Facility Monitoring Conditions

#	Terms and Conditions
32.	The Permittee shall measure the total monthly volume, calculate the daily average volume, and record the daily peak volume of wastewater received by the treatment facility each month using a primary measuring device (equipped with head sensing, totalizing and chart recording/data logging mechanisms) located at the headworks. The

#	Terms and Conditions
	Permittee shall submit the totalized, average daily, and peak daily influent volumes for each calendar month to NMED in the quarterly monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
33.	The Permittee shall on a monthly basis measure the volume of treated wastewater discharged from the effluent storage impoundments to <i>each</i> effluent disposal area. To determine the discharge volume, the Permittee shall maintain a log that records the daily discharges that occur to Effluent Disposal Area 1, 2, and 3 using two totalizing flow meters located on the two transfer lines between the disinfection unit and the effluent disposal areas. The Permittee shall use the log to calculate the monthly and average daily discharge volume. The Permittee shall use the calculated monthly volume discharged on the LADS (copy enclosed) to calculate nitrogen loading. The Permittee shall submit the calendar monthly meter readings, calculated monthly discharge volumes, and average daily discharge volumes to NMED in the quarterly monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
34.	During any quarter when the emergency leachfield (emergency disposal system) is used, the Permittee shall measure the monthly volume of treated wastewater discharged from the two synthetically lined storage impoundments to the emergency disposal system. The permittee shall obtain readings from a totalizing flow meter located after the disinfection unit on a monthly basis and calculate the monthly and average daily discharge volume. The monthly meter readings and calculated monthly and average daily discharge volumes shall be submitted to NMED in the quarterly monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
35.	All flow meters shall be capable of having their accuracy verified under working (i.e., real-time in-the-field) conditions. The Permittee shall develop a field verification method for each flow meter and shall utilize that method to check the accuracy of each respective meter. The Permittee shall perform field calibrations, at a minimum, on an annual basis. The Permittee shall also perform field calibrations upon repair or replacement of a flow measurement device. The Permittee shall calibrate each flow meter to its manufacturer's recommended specification which shall be no less accurate than plus or minus 10 percent of actual

#	Terms and Conditions
	flow, as measured under field conditions. An individual knowledgeable in flow measurement shall perform field calibration and the installation/operation of the device in use. The Permittee shall prepare a flow meter calibration report for each flow measurement device calibration event. The flow meter calibration report shall include the following information. - The location and meter identification. - The method of flow meter field calibration employed. - The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check. - The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter. - Any flow meter repairs made during the previous year or during field calibration. - The name of the individual performing the calibration and the date of the calibration. The Permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during Facility inspections. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
36.	The Permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. The Permittee shall maintain a log of the inspections that includes a date of the inspection, findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request. If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the Permittee shall repair or replace the meter within 30 days of discovery. For <i>repaired</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
37.	The Permittee shall collect samples of treated wastewater after the disinfection unit on a quarterly basis and analyze the samples for: TKN;

#	Terms and Conditions														
	• NO₃-N; • TDS; and • Cl. The Permittee shall ensure the samples are properly prepared, preserved, transported, and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, to NMED in the subsequent quarterly monitoring report. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]														
38.	During any month that the discharge of treated wastewater occurs to any effluent disposal area, the Permittee shall perform the following analyses on the wastewater samples collected after the chlorination station using the following sampling method and frequency: • Fecal Coliform or E. coli bacteria: grab sample at peak daily flow once per month; and • TRC concentrations: record whenever collecting bacteria samples. The Permittee shall ensure the samples are properly prepared, preserved, transported, and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, and a copy of the log of TRC concentrations to NMED in the quarterly monitoring report. [Subsection A of 20.6.2.3107 NMAC, Subsections B, C and H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]														
39.	Within one year of the issuance of this Discharge Permit (by DATE), the Permittee shall collect a 24-hour flow weighted composite sample (except as noted for pH) of treated wastewater after the disinfection unit and analyze the sample for the following inorganic contaminants (dissolved fraction, except as noted): <table border="0"> <tbody> <tr> <td>• aluminum (CAS 7429-90-5)</td><td>• manganese (CAS 7439-96-5)</td></tr> <tr> <td>• antimony (CAS 7440-36-0)</td><td>• molybdenum (CAS 7439-98-7)</td></tr> <tr> <td>• arsenic (CAS 7440-38-2)</td><td>• total mercury (nonfiltered) (CAS 7439-97-6)</td></tr> <tr> <td>• barium (CAS 7440-39-3)</td><td>• pH (instantaneous)</td></tr> <tr> <td>• beryllium (CAS 7440-41-7)</td><td>• nickel (CAS 7440-02-0)</td></tr> <tr> <td>• boron (CAS 7440-42-8)</td><td></td></tr> <tr> <td>• cadmium (CAS 7440-43-9)</td><td></td></tr> </tbody> </table>	• aluminum (CAS 7429-90-5)	• manganese (CAS 7439-96-5)	• antimony (CAS 7440-36-0)	• molybdenum (CAS 7439-98-7)	• arsenic (CAS 7440-38-2)	• total mercury (nonfiltered) (CAS 7439-97-6)	• barium (CAS 7440-39-3)	• pH (instantaneous)	• beryllium (CAS 7440-41-7)	• nickel (CAS 7440-02-0)	• boron (CAS 7440-42-8)		• cadmium (CAS 7440-43-9)	
• aluminum (CAS 7429-90-5)	• manganese (CAS 7439-96-5)														
• antimony (CAS 7440-36-0)	• molybdenum (CAS 7439-98-7)														
• arsenic (CAS 7440-38-2)	• total mercury (nonfiltered) (CAS 7439-97-6)														
• barium (CAS 7440-39-3)	• pH (instantaneous)														
• beryllium (CAS 7440-41-7)	• nickel (CAS 7440-02-0)														
• boron (CAS 7440-42-8)															
• cadmium (CAS 7440-43-9)															

#	Terms and Conditions
	- chromium (CAS 7440-47-3) - cobalt (CAS 7440-48-4) - copper (CAS 7440-50-8) - cyanide CAS 57-12-5) - fluoride (CAS 16984-48-8) - iron (CAS 7439-89-6) - lead (CAS 7439-92-1) - radioactivity: combined radium-226 & radium-228 (CAS 15262-20-1) - selenium (CAS 7782-49-2) - silver (CAS 7440-224) - sulfate (CAS 14808-79-8) - thallium (CAS 7440-28-0) - uranium (CAS 7440-61-1) - zinc (CAS 7440-66-6) The Permittee shall properly collect, prepare, preserve, transport, and analyze the samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall analyze the sample using methods with reporting limits that are less than the corresponding numerical groundwater standards identified in 20.6.2.3103 NMAC. The Permittee shall submit a summary of measured concentrations compared with the corresponding groundwater standards, a copy of the laboratory report including the laboratory analytical data results, the QA/QC summary and the Chain of Custody, to NMED in the subsequent monitoring report. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
40.	Within one year of the issuance of this Discharge Permit (by DATE), the Permittee shall collect a grab sample of treated wastewater after the disinfection unit and analyze the non-filtered sample for the following organic contaminants: - atrazine (CAS 1912-24-9) - benzene (CAS 71-43-2) - benzo-a-pyrene (CAS 50-32-8) - carbon tetrachloride (CAS 56-23-5) - chloroform (CAS 67-66-3) 1,2-dichlorobenzene (CAS 95-50-1) 1,4-dichlorobenzene (CAS 106-46-7) 1,1-dichloroethane (CAS 75-34-3) 1,2-dichloroethane (EDC, CAS 107-06-2) 1,1-dichloroethene (1,1-DCE, CAS 75-35-4) - cis-1,2-dichloroethene (CAS 156-59-2) - ethylene dibromide (EDB, CAS 106-93-4) - methylene chloride (CAS 75-09-2) - PAHs: total naphthalene (CAS 91-20-3) plus monomethylnaphthalenes - phenols - polychlorinated biphenyls (PCBs, CAS 1336-36-3) - pentachlorophenol (CAS 87-86-5) - toluene (CAS 108-88-3) - styrene (CAS 100-42-5) 1,1,2,2-tetrachloroethane (CAS 79-34-5) - tetrachloroethene (PCE, CAS 127-18-4) 1,2,4-trichlorobenzene (CAS 120-82-1)

#	Terms and Conditions
	• trans-1,2-dichloroethene (CAS 156-60-5) • 1,2-dichloropropane (PDC, CAS 78-87-5) • 1,4-dioxane (CAS 123-91-1) (using EPA Method 8270D- SIM) • ethylbenzene (CAS 100-41-4) • 1,1,1-trichloroethane (1,1,1-TCA, CAS 71-55-6) • 1,1,2-trichloroethane (CAS 79-00-5) • trichloroethene (TCE, CAS 79-01-6) • vinyl chloride (CAS 75-01-4) • total xylenes (CAS 1330-20-7) The Permittee shall properly collect, prepare, preserve, transport, and analyze the samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall analyze samples using methods with reporting limits that are less than the corresponding numerical groundwater standards identified in 20.6.2.3103 NMAC. The reporting limit for 1,4-dioxane shall be less than the Tap Water Screening Level for 1,4-dioxane identified in the <i>NMED Risk Assessment Guidance for Site Assessments and Investigations</i>, Table A-1 (available on the NMED Hazardous Waste Bureau's website under Guidance Documents). The Permittee shall submit a summary of measured concentrations compared with the corresponding groundwater standards, and a copy of the laboratory report including the laboratory analytical data results, the QA/QC summary and the Chain of Custody to NMED in the subsequent monitoring report. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
41.	The Permittee shall complete LADS (copy enclosed) on a monthly basis that document the amount of nitrogen applied to the three effluent disposal areas during the most recent 12 months. The LADS shall reflect the total nitrogen concentration from the most recent wastewater analysis and the measured discharge volumes to <i>each</i> effluent disposal area for each month. The Permittee shall complete the LADS for <i>each</i> disposal area with the information above or include a statement that application of wastewater did not occur. The Permittee shall submit the LADS to NMED in the subsequent quarterly monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]

C. CONTINGENCY PLAN

#	Terms and Conditions
42.	In the event that groundwater monitoring indicates that groundwater exceeds a standard identified in Section 20.6.2.3103 NMAC, the Permittee shall collect a confirmatory sample from the monitoring well within 15 days of receipt of the initial sampling results to confirm the initial sampling results. Within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule. The Permittee shall implement the CAP as approved by NMED. This condition shall apply until the Permittee completes groundwater monitoring for a minimum of eight (8) consecutive quarterly samples demonstrating groundwater does not exceed the standards of Section 20.6.2.3103 NMAC. Violation of the groundwater standard beyond 180 days after the confirmation of groundwater contamination may cause NMED to require the Permittee to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101, Section 20.6.2.4103, Subsections C and E of 20.6.2.4106, Section 20.6.2.4107, Section 20.6.2.4108 and Section 20.6.2.4112 NMAC. [20.6.2.3103 NMAC, Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]
43.	In the event that information available to NMED indicates that a well is not constructed in a manner consistent with the attached Monitoring Well Guidance, contains insufficient water to effectively monitor groundwater quality, or is otherwise not completed in a manner that is protective of groundwater quality, the Permittee shall install a replacement well(s) within 120 days following notification from NMED. The Permittee shall install replacement well(s) at locations approved by NMED prior to installation and shall complete replacement well(s) in accordance with the attached Monitoring Well Guidance. The Permittee shall submit well construction and lithologic logs to NMED within 60 days following well completion. The Permittee shall properly plug and abandon monitoring well(s) requiring replacement upon completion of the replacement monitoring well(s). The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the attached Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well(s) completion.

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC]
44.	In the event that the Facility exceeds the authorized discharge volume set in this Discharge Permit, the Permittee shall initiate the following Contingency Plan. <u>Contingency Plan</u> a) Notify NMED within seven days of the discovery of the discharge volume exceedance that the Facility exceeded the authorized discharge volume. b) The Permittee shall conduct a physical inspection of the discharge system, i.e., inflow and infiltration issues, collection system failures, etc., and the discharge meters to detect abnormalities and report the findings to NMED within 30 days of the discovery of the discharge volume exceedance. The Permittee shall correct any abnormalities detected with NMED's concurrence. c) If the Permittee does not detect any abnormalities and with NMED's concurrence, the Permittee shall submit a discharge permit modification for the increase in discharge quantity to NMED within 90 days of the discovery of the discharge volume exceedance. The discharge permit modification must include demonstration that the volume increase is sufficient for the design capacity or plans and specifications to upgrade the system to accommodate the discharge volume increase. [Subsection A of 20.6.2.3107 NMAC]
45.	In the event that analytical results of a treated wastewater sample indicate an exceedance of the total nitrogen discharge limit set in this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 48 hours of the receipt of the initial sampling results. In the event the second sample results indicate an exceedance of the discharge limit, the Permittee shall implement the following contingencies. a) Within 7 days of the second sample analysis date indicating exceedance of the discharge limit, the Permittee shall: i) notify NMED that the Permittee is implementing the Contingency Plan; and ii) submit a copy of the first and second analytical results indicating an exceedance to NMED. b) The Permittee shall increase the frequency of total nitrogen wastewater sampling and analysis of treated wastewater to once per month. c) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures. d) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities. The Permittee shall correct any abnormalities discovered. The

#	Terms and Conditions
	Permittee shall submit a report to NMED detailing the corrections within 30 days of correction. e) In the event that any analytical results from monthly wastewater sampling indicate an exceedance of the total nitrogen discharge limit, the Permittee shall submit a CAP to NMED for approval proposing to modify operational procedures and/or upgrade the treatment process to achieve the total nitrogen limit. The Permittee shall submit the CAP including a schedule for completion of corrective actions and within 90 days of receipt of the analytical results of the second sample indicating that the discharge continues to exceed the limit. The Permittee shall initiate implementation of the CAP following approval by NMED. When analytical results from three consecutive months of wastewater sampling do not exceed the discharge limit, the Permittee may request NMED authorize a return to a quarterly monitoring frequency. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
46.	In the event that analytical results of a treated wastewater sample exceed any of the maximum discharge limits for fecal coliform or E. coli bacteria set by this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 24 hours after becoming aware of the exceedance. In the event the second sample results confirm the exceedance of the maximum discharge limits, the Permittee shall implement the Contingency Plan below. In the event that analytical results of a treated wastewater sample indicate an exceedance of any of the 30-day average discharge limits for fecal coliform or E. coli bacteria set by this Discharge Permit (i.e., confirmed exceedance), the Contingency Plan below shall be implemented. <u>Contingency Plan</u> a) Within 48 hours of becoming aware of a confirmed exceedance (as identified above), the Permittee shall: i) notify NMED that the Permittee is implementing the Contingency Plan; and ii) submit copies of the recent analytical results indicating an exceedance to NMED. b) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures. c) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities. The Permittee shall correct any abnormalities discovered. The

#	Terms and Conditions
	Permittee shall submit a report detailing the corrections made to NMED within 30 days following correction. If a Facility is required to implement the Contingency Plan more than two times in a 12-month period, the Permittee shall propose to modify operational procedures and upgrade the treatment process to achieve consistent compliance with the maximum and 30-day average discharge limits by submitting a CAP for NMED approval within 60 days following receipt of the analytical results confirming the exceedance. The CAP shall include a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED. NMED may require the Permittee to cease discharging to the effluent disposal area(s) until the Permittee completes the approved corrective actions. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
47.	In the event that the LADS show that the amount of nitrogen in wastewater applied in any 12-month period in <i>any</i> of the three effluent disposal areas exceeds 200 pounds per acre, the Permittee shall propose the reduction of nitrogen loading to the affected disposal area by submitting a CAP to NMED for approval. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions and submit the CAP within 90 days following the end of the monitoring period in which the exceedance occurred. The Permittee shall implement the CAP following approval by NMED. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
48.	In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of an impoundment or liner or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a CAP to NMED for approval. The Permittee shall submit the CAP to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
49.	In the event that an impoundment cannot preserve a minimum of two feet of freeboard, the Permittee shall take actions to restore the required freeboard as authorized by this Discharge Permit and all applicable local, state, and federal regulations. In the event that two feet of freeboard cannot be restored within a period of 72 hours following discovery, the Permittee shall propose actions to restore two feet of

#	Terms and Conditions
	freeboard by submitting a short-term CAP to NMED for approval. Examples of short-term corrective actions include the pumping and hauling of excess wastewater from the impoundment or reducing the volume of wastewater discharged to the impoundment. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall submit the CAP within 15 days following the date the Permittee or the NMED discover the exceedance. The Permittee shall implement the CAP following NMED approval. In the event that the short-term corrective actions fail to restore two feet of freeboard, the Permittee shall submit to NMED a proposal for permanent corrective actions in a long-term CAP. The Permittee shall submit the long-term CAP within 90 days following failure of the short-term CAP. Examples of corrective actions include the installation of an additional storage impoundment or a significant and permanent reduction in the volume of wastewater discharged to the impoundment. The Permittee shall ensure the long-term CAP includes a schedule for completion of corrective actions. The Permittee shall implement the CAP following NMED approval. [Subsection A of 20.6.2.3107 NMAC]
50.	In the event the average solids accumulation exceeds one-third of the maximum liquid depth in the impoundments, the Permittee shall propose a plan for the removal and disposal of the solids. The Permittee shall submit the solids removal and disposal plan to NMED for approval within 120 days following discovery and include the following information. a) A method for removal of the solids to a depth of less than six inches throughout the treatment impoundment in a manner that is protective of the impoundment liner. b) A description of how the Permittee will contain, transport, and dispose of the solids in accordance with all local, state, and federal regulations, including 40 CFR Part 503. c) A schedule for completion of the solids removal and disposal project. The Permittee shall initiate implementation of the plan following approval by NMED. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
51.	In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of a sludge drying bed or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a CAP to NMED for approval. The Permittee shall submit the CAP to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED.

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
52.	In the event that the Permittee identifies failure of the emergency leachfield, such as surfacing wastewater, the Permittee shall implement the following Contingency Plan. a) Within 24 hours following the discovered failure, the Permittee shall: i) Notify NMED of the failure in accordance with the notification requirements described in the Contingency Plan for unauthorized discharges; and ii) Restrict public access to the area. b) The Permittee shall conduct a physical inspection of the treatment and disposal system to identify additional potential failures and record them in the inspection log. c) The Permittee shall propose actions to address the failure and methods of correction by submitting a CAP to NMED for approval within 15 days following the discovered failure. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following NMED approval. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
53.	In the event that a release occurs that is not authorized under this Discharge Permit (commonly known as a “spill”), the Permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below. A release is defined as such quantity as may with reasonable probability injure or be detrimental to human health, animal or plant life, or property, or unreasonably interfere with the public welfare or the use of property. Within <u>24 hours</u> following discovery of the unauthorized discharge, the Permittee shall verbally notify NMED and provide the following information. a) The name, address, and telephone number of the person or persons in charge of the Facility, as well as of the owner and/or operator of the Facility. b) The name and address of the Facility. c) The date, time, location, and duration of the unauthorized discharge. d) The source and cause of unauthorized discharge. e) A description of the unauthorized discharge, including its estimated chemical composition. f) The estimated volume of the unauthorized discharge. g) Any actions taken to mitigate immediate damage from the unauthorized discharge.

#	Terms and Conditions
	Within <u>one week</u> following discovery of the unauthorized discharge, the Permittee shall submit written notification to NMED providing the information listed above and any pertinent updates. Within <u>15 days</u> following discovery of the unauthorized discharge, the Permittee shall submit a CAP to NMED describing any corrective actions previously taken and corrective actions to be taken relative to the unauthorized discharge. The CAP shall include the following information. a) A description of proposed actions to mitigate damage from the unauthorized discharge. b) A description of proposed actions to prevent future unauthorized discharges of this nature. c) A schedule for completion of proposed actions. In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, NMED may require the Permittee to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC. The Permittee shall not construe anything in this condition as relieving them of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC. [20.6.2.1203 NMAC]
54.	In the event that NMED or the Permittee identifies any failures of the discharge plan, i.e., the application, or this Discharge Permit not specifically noted herein, NMED may require the Permittee to submit a CAP and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a discharge permit modification to achieve compliance with 20.6.2 NMAC. [Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]

D. CLOSURE PLAN

Permanent Facility Closure Conditions

#	Terms and Conditions
55.	The Permittee shall perform the following closure measures in the event the Facility, or a component of the Facility, is proposed to be permanently closed. Within <u>90 days</u> of ceasing to discharge to the treatment system, the Permittee shall complete the following closure measures. a) Plug the line leading to the system so that a discharge can no longer occur. b) Evaporate wastewater in the system components and storage impoundments, drain and dispose of in accordance with all local, state, and federal regulations, or discharged from the system to the effluent disposal areas as authorized by this Discharge Permit. The discharge of accumulated solids (sludge) to the effluent disposal areas is prohibited. c) Contain, transport, and dispose of solids removed from the treatment system in accordance with all local, state, and federal regulations, including 40 CFR Part 503. The Permittee shall maintain a record of all solids transported for off-site disposal. Within <u>180 days</u> of ceasing to discharge to the treatment system (or unit), the Permittee shall complete the following closure measures. a) Remove all lines leading to and from the treatment system or permanently plug and abandon them in place. b) Remove or demolish all treatment system components (with the exception of the emergency leach field), and re-grade the area with suitable fill to blend with surface topography, promote positive drainage, and prevent ponding. c) Perforate or remove the storage impoundment liners; fill the impoundments with suitable fill; and re-grade the impoundment sites to blend with surface topography, promote positive drainage, and prevent ponding. The Permittee shall continue groundwater monitoring until the Permittee meets the requirements of this condition and groundwater monitoring confirms for a minimum of eight consecutive quarterly groundwater sampling events that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC. This period is referred to as “post-closure.” If at any time monitoring results show an exceedance of a groundwater quality standard in Section 20.6.2.3103 NMAC, the Permittee shall implement the Contingency Plan required by this Discharge Permit. Following notification from NMED that the Permittee may cease post-closure monitoring, the Permittee shall plug and abandon the monitoring well(s) in accordance with the attached Monitoring Well Guidance.

#	Terms and Conditions
	When the Permittee has met all closure requirements and verified appropriate actions with date stamped photographic evidence or an associated NMED inspection, the Permittee may submit to NMED a written request, including photographic evidence, for termination of the Discharge Permit. [Subsection A of 20.6.2.3107 NMAC, Subsection D of 20.6.2.4103 NMAC, 40 CFR Part 503]

E. GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
56.	RECORD KEEPING - The Permittee shall maintain a written record of the following: • Information and data used to complete the application for this Discharge Permit; • Information, data, and documents demonstrating completion of closure activities; • Any releases (commonly known as “spills”) not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC; • The operation, maintenance, and repair of all facilities/equipment used to treat, store, or dispose of wastewater; • Facility record drawings (plans and specifications) showing the actual construction of the Facility and bear the seal and signature of a licensed New Mexico professional engineer; • Copies of logs, inspection reports, and monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit; • The volume of wastewater or other wastes discharged pursuant to this Discharge Permit; • Wastewater quality data collected pursuant to this Discharge Permit; • The maintenance, repair, replacement, or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and • Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including: ○ the dates, locations, and times of sampling or field measurements; ○ the name and job title of the individuals who performed each sample collection or field measurement; ○ the sample analysis date of each sample; ○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis; ○ the analytical technique or method used to analyze each sample or collect each field measurement; ○ the results of each analysis or field measurement, including raw data;

#	Terms and Conditions
	○ the results of any split, spiked, duplicate, or repeat sample; and ○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. The Permittee shall maintain the written record at a location accessible to NMED during a Facility inspection for a minimum of five years. The Permittee shall make the record available to NMED upon request. [Subsections A and D of 20.6.2.3107 NMAC]
57.	SUBMITTALS - The Permittee shall submit both a paper copy and an electronic copy of all notification and reporting documents required by this Discharge Permit, e.g., monitoring reports. The Permittee shall submit paper and electronic documents to the NMED Permit Contact identified on the Permit cover page. [Subsection A of 20.6.2.3107 NMAC]
58.	INSPECTION and ENTRY - The Permittee shall allow NMED to inspect the Facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may, upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which any maintained records required by this Discharge Permit, the regulations of the federal government, or the WQCC are located. The Permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations. No person shall construe anything in this Discharge Permit as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state, or federal regulations. [Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]
59.	DUTY to PROVIDE INFORMATION - The Permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records. [Subsection D of 20.6.2.3107 NMAC]
60.	MODIFICATIONS and/or AMENDMENTS - In the event the Permittee proposes a change to the Facility or the Facility's discharge that would result in a change in the volume

#	Terms and Conditions
	discharged; the location of the discharge; or in the amount or character of water contaminants received, treated, or discharged by the Facility, the Permittee shall notify NMED prior to implementing such changes. The Permittee shall obtain NMED's approval (which may require modification of this Discharge Permit) prior to implementing such changes. [Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]
61.	PLANS and SPECIFICATIONS - In the event the Permittee proposes to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the Permittee shall submit construction plans and specifications of the proposed system or process unit to NMED for approval prior to the commencement of construction. In the event the Permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the Permittee shall report such changes (including the submission of record drawings where applicable) to NMED prior to implementation. [Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]
62.	CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the Permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the Permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit. [20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]
63.	CRIMINAL PENALTIES - No person shall:

#	Terms and Conditions
	• Make any false material statement, representation, certification, or omission of material fact in an application, record, report, plan, or other document filed, submitted, or maintained under the WQA; • Falsify, tamper with, or render inaccurate any monitoring device, method, or record maintained under the WQA; or • Fail to monitor, sample, or report as required by a permit issued pursuant to a state or federal law or regulation. Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. [20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]
64.	COMPLIANCE with OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the Permittee of the obligation to comply with any other applicable federal, state, and/or local laws, regulations, zoning requirements, nuisance ordinances, permits, or orders. [NMSA 1978, § 74-6-5.L]
65.	RIGHT to APPEAL - The Permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues raised and the relief sought. Unless the Permittee files a timely petition for review, the decision of NMED shall be final and not subject to judicial review. [20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]
66.	TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this Facility or any portion thereof, the Permittee shall:

#	Terms and Conditions
	• Notify the proposed transferee in writing of the existence of this Discharge Permit; • Include a copy of this Discharge Permit with the notice; and • Deliver or send by certified mail to NMED a copy of the notification and proof that the proposed transferee has received such notification. The Permittee shall continue to be responsible for any discharge from the Facility, until both ownership and possession of the Facility have been transferred to the transferee. [20.6.2.3111 NMAC]
67.	PERMIT FEES - The Permittee shall be aware that the payment of permit fees is due at the time of Discharge Permit approval. The Permittee may pay the permit fees in a single payment or they may pay the fee in equal installments on a yearly basis over the term of the Discharge Permit. The Permittee shall remit single payments to NMED no later than 30 days after the Discharge Permit issuance date. The Permittee shall remit initial installment payments to NMED no later than 30 days after the Discharge Permit issuance date; with subsequent installment payments remitted to NMED no later than the anniversary of the Discharge Permit issuance date. Permit fees are associated with <u>issuance</u> of this Discharge Permit. No person shall construe anything in this Discharge Permit as relieving the Permittee of the obligation to pay all permit fees assessed by NMED. A Permittee that ceases discharging or does not commence discharging from the Facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. NMED shall suspend or terminate an approved Discharge Permit if the Permittee fails to remit an installment payment by its due date. [Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Facility Information

Facility Name West Mesa / Santa Teresa Wastewater Treatment Facility
Discharge Permit Number DP-1281
Legally Responsible Party Juan Carlos Crosby, Executive Director
Camino Real Regional Utility Authority
P.O. Box 429
Sunland Park, New Mexico 88063
(575) 589-1075

Treatment, Disposal and Site Information

Primary Waste Type Domestic/Industrial
Facility Type MUNI-Wastewater

Treatment Methods

Type	Designation	Description & Comments
Wastewater Treatment System	Wastewater Treatment Facility (WWTF)	Intermittent cycle (SBR) extended aeration treatment system with five basins and a total capacity of 658,240 gallons. System includes three basins for the aerobic digesting of sludge with a total capacity of 160,000 gallons. Treated wastewater is disinfected using chlorine disinfection.

Discharge Locations

Type	Designation	Description & Comments
Impoundment	Effluent Storage Impoundment 1	A 314,000 gallon (0.33 acre) synthetically lined storage impoundment.
Impoundment	Effluent Storage Impoundment 2	A 719,000 gallon (0.33 acre) synthetically lined storage impoundment.
Sludge Drying Beds	Sludge Drying Beds	Three asphalt-lined sludge drying beds (5,400 ft ²).
Surface Disposal Area	Effluent Disposal Area 1	Treated wastewater disposal via surface spray by center pivot to 11.2 acres of natural vegetation.
Surface Disposal Area	Effluent Disposal Area 2	Treated wastewater disposal via surface spray by center pivot to 11.5 acres of natural vegetation.
Surface Disposal Area	Effluent Disposal Area 3	Treated wastewater disposal via surface spray by center pivot to 26 acres of natural vegetation.
Injection Well/UIC	Emergency Leachfield	Eight galleries consisting of infiltrators, 18 rows of 16 infiltrators each.

Flow Metering Locations

Type	Designation	Description & Comments
Primary Measurement Device	Influent Flow Meter	A Parshall Flume with an ultrasonic flow sensor located at the headworks after the bar screen.



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Totalizing Flow Meter	Treated Wastewater Flow Meters	Two totalizing flow magmeters located at the Effluent Pump Station on the discharge line to the three effluent disposal areas and the emergency leachfield.
-----------------------	--------------------------------	---

Depth-to-Ground Water 315 feet
Total Dissolved Solids (TDS) 500-1,000 mg/L

Permit Information

Original Permit Issued July 25, 2000
Permit Renewal January 3, 2009
Permit Renewal April 14, 2014
Permit Modification June 16, 2017
Permit Renewal May 29, 2019

Current Action
Application Received
Public Notice Published
Permit Issued (Issuance Date)
Permitted Discharge Volume

Permit Renewal
June 5, 2024
[not yet published]
[issuance date]
600,000 gallons per day

NMED Contact Information

Mailing Address
Ground Water Quality Bureau
P.O. Box 5469
Santa Fe, New Mexico 87502-5469

GWQB Telephone Number
(505) 827-2900

NMED Lead Staff
Haylea Nisbet
Lead Staff Telephone Number
(505) 795-2831
Lead Staff Email
haylea.nisbet@env.nm.gov or pps.general@env.nm.gov

Groundwater Discharge Permit Guidance for Synthetically Lined Lagoons – Liner Material and Site Preparation

This guidance document represents minimum liner material and site preparation requirements for wastewater treatment, storage and evaporation lagoons. These requirements do not apply to lagoons storing hazardous wastes or high strength waste. The Ground Water Quality Bureau may impose additional requirements (e.g., double-lined lagoons with leak detection) for facilities discharging hazardous or high strength waste to lagoons through the development of specific Discharge Permit conditions for such facilities.

Liner Material Requirements:

1. The liner shall be chemically compatible with any material that will contact the liner.
2. The liner material shall be resistant to deterioration by sunlight if any portion of the liner will be exposed.
3. Synthetic liner material shall be of sufficient thickness to have adequate tensile strength and tear and puncture resistance. Under no circumstances shall a synthetic liner material less than 40 mils in thickness be accepted. Any liner material shall be certified by a licensed New Mexico professional engineer and approved by the New Mexico Environment Department (NMED) prior to its installation.

Lagoon Design and Site Preparation Requirements:

1. The system shall be certified by a licensed New Mexico professional engineer and approved by NMED prior to installation.
2. Inside slopes shall be a maximum of 3 (horizontal): 1 (vertical), and a minimum of 4 (horizontal); 1 (vertical).
3. Lagoon volume shall be designed to allow for a minimum of 24 inches of freeboard.
4. The liner shall be installed with sufficient liner material to accommodate shrinkage due to temperature changes. Folds in the liner are not acceptable.
5. To a depth of at least six inches below the liner, the sub-grade shall be free of sharp rocks, vegetation and stubble. In addition, liners shall be placed on a sub-grade of sand or fine soil. The surface in contact with the liner shall be smooth to allow for good contact between liner and sub-grade. The surface shall be dry during liner installation.
6. Sub-grade shall be compacted to a minimum of 90% of standard proctor density.
7. The minimum dike width shall be eight feet to allow vehicle traffic for maintenance.
8. The base of the pond shall be as uniform as possible and shall not vary more than three inches from the average finished elevation.
9. Synthetic liners shall be anchored in an anchor trench in the top of the berm. The trench shall be a minimum of 12 inches wide, 12 inches deep and shall be set back at least 24 inches from the inside edge of the berm.
10. If the lagoon is installed over areas of decomposing organic materials or shallow groundwater, a liner vent system shall be installed.
11. Any opening in the liner through which a pipe or other fixture protrudes shall be properly sealed. Liner penetrations shall be detailed in the construction plans and record drawings.
12. A synthetic liner shall not be installed in temperatures below freezing.
13. The liner shall be installed or supervised by an individual that has the necessary training and experience as required by the liner manufacturer.
14. All manufacturer's installation and field seaming guidelines shall be followed.
15. All synthetic liner seams shall be field tested by the installer and verification of the adequacy of the seams shall be submitted to NMED along with the record drawings.
16. Concrete slabs installed on top of the synthetic liner for operational purposes shall be completed in accordance with manufacturer and installer recommendations to ensure liner integrity.

**NEW MEXICO ENVIRONMENT DEPARTMENT
GROUND WATER QUALITY BUREAU
MONITORING WELL CONSTRUCTION AND ABANDONMENT GUIDELINES**

Purpose: These guidelines identify minimum construction and abandonment details for installation of water table monitoring wells under groundwater Discharge Permits issued by the NMED's Ground Water Quality Bureau (GWQB) and Abatement Plans approved by the GWQB. Proposed locations of monitoring wells required under Discharge Permits and Abatement Plans and requests to use alternate installation and/or construction methods for water table monitoring wells or other types of monitoring wells (e.g., deep monitoring wells for delineation of vertical extent of contaminants) must be submitted to the GWQB for approval prior to drilling and construction.

General Drilling Specifications:

1. All well drilling activities must be performed by an individual with a current and valid well driller license issued by the State of New Mexico in accordance with 19.27.4 NMAC. Use of drillers with environmental well drilling experience and expertise is highly recommended.
2. Drilling methods that allow for accurate determinations of water table locations must be employed. All drill bits, drill rods, and down-hole tools must be thoroughly cleaned immediately prior to the start of drilling. The borehole diameter must be drilled a minimum of 4 inches larger than the casing diameter to allow for the emplacement of sand and sealant.
3. After completion, the well should be allowed to stabilize for a minimum of 12 hours before development is initiated.
4. The well must be developed so that formation water flows freely through the screen and is not turbid, and all sediment and drilling disturbances are removed from the well.

Well Specifications (see attached monitoring well schematic):


5. Schedule 40 (or heavier) polyvinyl chloride (PVC) pipe, stainless steel pipe, carbon steel pipe, or pipe of an alternate appropriate material that has been approved for use by NMED must be used as casing. The casing must have an inside diameter not less than 2 inches. The casing material selected for use must be compatible with the anticipated chemistry of the groundwater and appropriate for the contaminants of interest at the facility. The casing material and thickness selected for use must have sufficient collapse strength to withstand the pressure exerted by grouts used as annular seals and thermal properties sufficient to withstand the heat generated by the hydration of cement-based grouts. Casing sections may be joined using welded, threaded, or mechanically locking joints; the method selected must provide sufficient joint strength for the specific well installation. The casing must extend from the top of the screen to at least one foot above ground surface. The top of the casing must be fitted with a removable cap, and the exposed casing must be protected by a locking steel well shroud. The shroud must be large enough in diameter to allow easy access for removal of the cap. Alternatively, monitoring wells may be completed below grade. In this case, the casing must extend from the top of the screen to 6 to 12 inches below the ground surface; the monitoring wells must be sealed with locking, expandable well plugs; a flush-mount, watertight well vault that is rated to withstand traffic loads must be emplaced around the wellhead; and the cover must be secured with at least one bolt. The vault cover must indicate that the wellhead of a monitoring well is contained within the vault.
6. A 20-foot section (maximum) of continuous-slot, machine slotted, or other manufactured PVC or stainless steel well screen or well screen of an alternate appropriate material that has been approved for use by NMED must be installed across the water table. Screens created by cutting slots into solid casing with saws or other tools must not be used. The screen material selected for use must be compatible with the anticipated chemistry of the ground water and appropriate for the contaminants of interest at the facility. Screen sections may be joined using welded, threaded, or mechanically

- locking joints; the method selected must provide sufficient joint strength for the specific well installation and must not introduce constituents that may reasonably be considered contaminants of interest at the facility. A cap must be attached to the bottom of the well screen; sumps (i.e., casing attached to the bottom of a well screen) should not be installed. The bottom of the screen must be installed no more than 15 feet below the water table; the top of the well screen must be positioned not less than 5 feet above the water table. The well screen slots must be appropriately sized for the formation materials and should be selected to retain 90 percent of the filter pack. A slot size of 0.010 inches is generally adequate for most installations.
7. Casing and well screen must be centered in the borehole by placing centralizers near the top and bottom of the well screen.
 8. A filter pack must be installed around the screen by filling the annular space from the bottom of the screen to 2 feet above the top of the screen with clean silica sand. The filter pack must be properly sized to prevent fine particles in the formation from entering the well; clean medium to coarse silica sand is generally adequate as filter pack material for 0.010-inch slotted well screen. For wells deeper than 30 feet, the sand must be emplaced by a tremmie pipe. The well should be surged or bailed to settle the filter pack and additional sand added, if necessary, before the bentonite seal is emplaced.
 9. A bentonite seal must be constructed immediately above the filter pack by emplacing bentonite chips or pellets (3/8-inch in size or smaller) in a manner that prevents bridging of the chips/pellets in the annular space. The bentonite seal must be 3 feet in thickness and hydrated with clean water. Adequate time should be allowed for expansion of the bentonite seal before installation of the annular space seal.
 10. The annular space above the bentonite seal must be sealed with cement grout or a bentonite-based sealing material acceptable to the State Engineer pursuant to 19.27.4 NMAC. A tremmie pipe must be used when placing sealing materials at depths greater than 20 feet below the ground surface. Annular space seals must extend from the top of the bentonite seal to the ground surface (for wells completed above grade) or to a level 3 to 6 inches below the top of casing (for wells completed below grade).
 11. For monitoring wells finished above grade, a concrete pad (2-foot minimum radius, 4-inch minimum thickness) must be poured around the shroud and wellhead. The concrete and surrounding soil must be sloped to direct rainfall and runoff away from the wellhead. The installation of steel posts around the well shroud and wellhead is recommended for monitoring wells finished above grade to protect the wellhead from damage by vehicles or equipment. For monitoring wells finished below grade, a concrete pad (2-foot minimum radius, 4-inch minimum thickness) must be poured around the well vault and wellhead. The concrete and surrounding soil must be sloped to direct rainfall and runoff away from the well vault.

Abandonment:

12. Approval for abandonment of monitoring wells used for ground water monitoring in accordance with Discharge Permit and Abatement Plan requirements must be obtained from NMED prior to abandonment.
13. Well abandonment must be accomplished by removing the well casing and placing neat cement grout, bentonite-based plugging material, or other sealing material approved by the State Engineer for wells that encounter water pursuant to 19.27.4 NMAC from the bottom of the borehole to the ground surface using a tremmie pipe. If the casing cannot be removed, neat cement grout, bentonite-based plugging material, or other sealing material approved by the State Engineer must be placed in the well using a tremmie pipe from the bottom of the well to the ground surface.
14. After abandonment, written notification describing the well abandonment must be submitted to the NMED. Written notification of well abandonment must consist of a copy of the well plugging record submitted to the State Engineer in accordance with 19.27.4 NMAC, or alternate documentation containing the information to be provided in a well plugging record required by the State Engineer as specified in 19.27.4 NMAC.

Deviation from Monitoring Well Construction and Abandonment Requirements: Requests to construct water table monitoring wells or other types of monitoring wells for groundwater monitoring under groundwater Discharge Permits or Abatement Plans in a manner that deviates from the specified requirements must be submitted in writing to the GWQB. Each request must state the rationale for the proposed deviation from these requirements and provide detailed evidence supporting the request. The GWQB will approve or deny requests to deviate from these requirements in writing.




New Mexico Environment Department - Ground Water Quality Bureau
Guidance: How To Sample A Monitoring Well

Tools Needed Checklist		Check box
1	Long measuring tape (You'll need it to be long enough to reach the bottom of your well) <u>Or</u> electronic water level meter.	
2	Bailer(s): A 5 ft section of 2 or 3 inch PVC pipe with a check valve on one end and a wire loop on the other allowing you to lower it down the well with rope and pull it up full of water. <u>Or</u> Submersible Pump: A portable generator/battery may be required if an electrical source is not available.	
3	Sample containers: Clean plastic gallon containers or sample bottles supplied by the lab. The number of containers you need will depend on the lab's requirements, contact the lab for instructions. Generally, you can use one container for Total Kjeldahl Nitrogen (TKN) and Nitrate (NO ₃ -N) and another for Total Dissolved Solids (TDS) and Chloride (Cl).	
4	Distilled water (DI) and bucket	
5	Gloves	
6	Pen, Paper, Calculator	
7	Copy of your discharge permit with a site map and monitoring well (MW) logs	
8	Cooler with Ice	

Tips for using a Bailer	
1	Before lowering the bailer into the well check to see that it is securely fastened to the rope. Secure the other end of the rope to prevent losing the bailer down the well.
2	Lower the bailer into the well in a controlled manner until it hits the water. (You will either hear it hit the water or feel the difference in the tension of the rope.)
3	Lower the bailer a few more feet and allow it to fill with water. Try to keep the bailer near the surface of the water to prevent collecting sediment.
4	Repeat the process as many times as necessary to purge and sample required volume.
5	If you are sampling alone, use the tarp to keep your rope and bailer from touching the soil.
6	Test the check valve periodically to prevent clogging.

Example Sample Label	
Site Name: _____	DP #: _____
Sample Location (e.g. MW-1): _____	
Sampled for (e.g. nitrate): _____	
Sampled by: _____	
Date: _____	Time: _____



Sampling Procedures

New Mexico Environment Department - Ground Water Quality Bureau

Guidance: How To Sample A Monitoring Well

of well in Inches	1	1.5	2	3	4	6	8	10	12
Volume in Gallons per Linear Foot	0.04	0.1	0.17	0.38	0.66	1.5	2.6	4.09	5.81

Table 2: Purge Calculator*

Monitoring well #	A** Top of Well Casing (Step 6.B)	B** Water Line (Step 6.C)	C** Depth to Water (A-B) (Step 6.D)	D** Total Well Depth (Step 1.4)	E Liner Feet of Water in well (D-C) (Step 7.A)	F Diameter of well (Step 7.B)	G Gallons of water per liner foot (Step 7.B)	H Volume of Water in Well (G X E) (Step 7.B)	I Purge Volume in gallons (H X 3)
1			0.0		0.0			0.0	0.0
2			0.0		0.0			0.0	0.0
3			0.0		0.0			0.0	0.0
4			0.0		0.0			0.0	0.0
5			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0
			0.0		0.0			0.0	0.0

*If using in an open excel file, the purge calculator will automatically calculate values shaded in blue. Otherwise follow the sampling procedures on the previous page to calculate your well purge volume.

** units are in feet

Groundwater Monitoring Worksheet and Reference Chart

Monitoring well # and location	A Top of well casing (Step 6.c.)	B Water Line (Step 6.d.)	C Depth to water (A - B) (Step 6.e.)	D Total depth of well (Step 1.e.)

E Linear feet of water in well (D - C) (Step 7.b)	F Diameter of well (Step 7.c.)	G Gallons of water per linear foot (Step 7.d.)	H Volume of water in the well (G x E) (Step 7.e.)	I Volume of water to be purged (H x 3) (Step 8.a.)

Reference Chart

Inside well diameter (inches)	Gallons of water per linear foot
1	.04
2	.16
3	.37
4	.65
6	1.47
8	2.61
10	4.08
12	5.88

Example of Sample Label

Site Name: _____ DP # _____

Date of sampling: _____ Time of sampling: _____

Location of sampling (e.g. monitoring well ID/location): _____

Constituents sampled for (e.g. TKN, TDS, etc....) _____

Sample taken by: _____

Land Application Data Sheet (LADS)
Treated Domestic Wastewater

New Mexico Environment Department
Ground Water Quality Bureau



DATE: MONITORING REPORT DUE DATE:

FACILITY NAME: REPORTING PERIOD (i.e., from ___ to ___):

DP#: FIELD / ZONE ID:¹ # ACRES IN FIELD / ZONE²:

MONTH & YEAR OF DISCHARGE ³	A MEASURED VOLUME OF WASTEWATER DISCHARGED ⁴ gallons	B WASTEWATER QUALITY DATA ⁵ (TKN + NO ₃ -N) mg/L	C WASTEWATER DISCHARGED (A ÷ 1,000,000) million gallons (MG)	D TOTAL NITROGEN DISCHARGED (B x C x 8.34 lb/gal) lbs N	E NITROGEN LOADING (D ÷ # acres) lbs N/acre	NOTES ⁶
<i>example assuming a 150-acre field: MM - YY</i>	<i>4,887,750 gal</i>	<i>4.2 mg/L TKN + 15.1 mg/L NO₃-N = 19.3 mg/L</i>	<i>4,887,750 gal / 1,000,000 = 4.89 MG</i>	<i>19.3 mg/L x 4.89 MG x 8.34 lb/gal = 787 lbs N</i>	<i>787 lbs / 150 acres = 5.2 lb N/ac</i>	<i>flood application</i>
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
			0.00	0		
TOTALS				0		

¹One LADS form should be used for *each* field/zone (may include subsurface irrigation area, leachfield, golf course, field within a re-use area, etc.).

²For leachfields with an absorpotion area in square-feet, 1 acre = 43,560 ft².

³Each form must reflect the *most recent* 12 months of wastewater discharge.

⁴Monthly volume of gallons discharged; if measured in acre-ft, multiply by 325,850.

⁵This information should be obtained from the *most recent* laboratory analysis. When sampling quarterly, record the same data for the three months of that monitoring quarter.

⁶In the event discharge did not occur, please report "no discharge" in the NOTES column.

The use of additional fertilizers is required to be reported. Please complete the "Fertilizer Log" form and attach it to the LADS.