



CERTIFIED MAIL – RETURN RECEIPT REQUESTED

July 15, 2024

Ludovic Pasqualinotto, Facility Representative
Lea Power Partners, LLC
98 N. Twombly Lane
Hobbs, New Mexico 88240

RE: Draft Discharge Permit Renewal, DP-1620, Hobbs Generating Station

Dear Ludovic Pasqualinotto:

The New Mexico Environment Department (NMED) hereby provides notice to you of the proposed approval of Ground Water Discharge Permit Renewal, DP-1620 (copy enclosed), pursuant to Subsection H of 20.6.2.3108 NMAC. NMED will publish notice of the availability of the draft Discharge Permit in the near future for public review and comment and will forward a copy of that notice to you.

Prior to making a final ruling on the proposed Discharge Permit, NMED will allow 30 days from the date the public notice is published in the newspaper for any interested party, including the Discharge Permit applicant, i.e., yourself, to submit written comments and/or a request a public hearing. A hearing request shall set forth the reasons why a hearing is requested. NMED will hold a hearing in response to a timely hearing request if the NMED Secretary determines there is substantial public interest in the proposed Discharge Permit.

NMED sent you a draft permit dated April 29, 2024. Lea Power Partners (LPP) responded to the draft on May 23, 2024, with seven comments and NMED provides the following responses:

LPP's Comment: (paraphrased) LPP disagrees with the statement from NMED regarding supplemental fresh water from a private well is used to augment irrigation and to reduce the salinity of the impoundment water" as indicated in the draft Permit, Section I Introduction, last sentence, paragraph 4.

NMED's Response: NMED has deleted this sentence.

LPP's Comment: (Page 3, Findings #2) LPP disagrees with the statement from NMED: "The Permittee is discharging effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit" as indicated in the draft Permit, Section 2 Findings, paragraph 2.

Response: This is standard language and NMED will retain this language in the permit.

LPP's Comment: (Page 9-11, Conditions #17 through 20) (Paraphrased) LPP asks NMED to review this section of the draft permit, as it is unclear if this section is complete.

NMED's Response: This section is complete and details the series of conditions that are contingent upon successful completion of previous steps regarding either the reconfiguration of MW-4A or constructing a new monitoring well MW-4B.

LPP's Comment: LPP indicates that several sections of the permit report the need for sample and reporting events for calendar year 2023, which has already passed.

NMED's Response: NMED has changed the permit requirements from calendar year 2023 to 2025, and others as appropriate.

LPP's Comment: (Page 18, Condition #32) (paraphrased) LPP discusses the new requirement to submit a study to NMED that includes an investigation of the impacts of the current and past wastewater disposal methods, as noted in the draft Permit Part IV, Section C, Additional Studies Required, Condition #32. LPP would like NMED to include language in the permit, which would allow the Facility ample time to develop a plan for alternative disposal methods if NMED makes an adverse determination against the Facility.

NMED's Response: NMED has changed the language to read: "The Permittee shall submit an application for modification to NMED that includes an alternative disposal method within one year of the Date of Determination, and concurrently limit discharge to the land application area to the extent possible while maintaining two feet of freeboard in the storage impoundments."

NMED removed the following language: "The Permittee shall suspend the current disposal practices and shall submit an application for modification to NMED that includes an alternative disposal method within one year of the Date of Determination."

If additional time is required, LPP may submit a request to NMED for an extension of time to develop an alternative disposal method plan.

LPP's Comment: (Page 19, Condition #33) LPP acknowledges the newly worded requirement that "within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule" as noted in the draft Permit's Part IV, Section D, Additional Studies Required, Condition #33. While LPP does acknowledge the newly worded requirement, we would like to understand how NMED expects the Facility to comply with this requirement, especially the freshly added verbiage, as the groundwater in the area around MW-4 (first drilled down gradient well) and MW-4A have clearly shown to NMED that the groundwater exceeds the standard identified in Section 20.6.2.3103 NMAC even before the Facility started land applying any effluent or leachate to the irrigation area.

NMED's Response: This is standard language and NMED will retain this language for the permit. NMED does not agree that LPP has "clearly shown to NMED" that the groundwater exceeds the standard identified in Section 20.6.2.3103 NMAC even before the Facility started land applying any effluent or leachate to the irrigation area. If additional time is required, LPP can submit a request to NMED for an extension of time.

Please review the enclosed draft Discharge Permit carefully. Please be aware that this Discharge Permit may contain conditions that require the permittee to implement operational, monitoring or closure actions by a specified deadline.

Lee Power Partners, LLP

July 15, 2024

Page 3 of 3

Please submit written comments or a request for hearing to my attention at the address below, via email to Kathleen.Murphy@env.nm.gov or to pps.general@env.nm.gov, or directly into the NMED Public Comment Portal at <https://nmed.commentinput.com/comment/search>. If NMED does not receive written comments or a request for hearing during the public comment period, the draft Discharge Permit will become final.

Thank you for your cooperation during the review process. Feel free to contact me with any questions at (505) 660-7567.

Sincerely,

Kathleen Murphy, Water Resource Professional

Encl: Draft Discharge Permit Renewal, DP-1620



NEW MEXICO
ENVIRONMENT DEPARTMENT
 Ground Water Quality Bureau
 1190 Saint Francis Drive / PO Box 5469
 Santa Fe, NM 87502-5469
 Phone (505) 827-2900 Fax (505) 827-2965
www.env.nm.gov



Draft: July 15, 2024

GROUND WATER QUALITY BUREAU
DISCHARGE PERMIT
Issued under 20.6.2 NMAC

Facility Name:	Hobbs Generating Station
Discharge Permit Number:	DP-1620
Facility Location:	98 N. Twombly Lane Hobbs, New Mexico 88204
County:	Lea
Permittee:	Lea Power Partners, LLC
Mailing Address:	98 N. Twombly Lane Hobbs, New Mexico 88204
Facility Contact:	Ludovic Pasqualinotto
Telephone Number/Email:	575-397-6706 / Ludovic.Pasqualinotto@contourglobal.com
Permitting Action:	Renewal
Permit Issuance Date:	DATE
Permit Expiration Date:	DATE
NMED Permit Contact:	Kathleen Murphy, Water Resource Professional
Telephone Number/Email:	505-660-7567 / Kathleen.Murphy@env.nm.gov or pps.general@env.nm.gov

JUSTIN D. BALL
 Chief, Ground Water Quality Bureau
 New Mexico Environment Department

Date

TABLE OF CONTENTS

II. FINDINGS 3

III. AUTHORIZATION TO DISCHARGE 4

IV. CONDITIONS 4

A. OPERATIONAL PLAN 4
 Operating Conditions 4

B. MONITORING AND REPORTING 8
 Due Dates for Monitoring Reports 9
 Monitoring Actions with Implementation Deadlines 9
 Groundwater Monitoring Conditions 11
 Facility Monitoring Conditions 13

C. ADDITIONAL STUDIES REQUIRED 18

D. CONTINGENCY PLAN 19

E. CLOSURE PLAN 23
 Closure Actions with Implementation Deadlines 23
 Permanent Facility Closure Conditions 27

F. GENERAL TERMS AND CONDITIONS 28

ATTACHMENTS

- Discharge Permit Summary
- New Mexico Environment Department Ground Water Quality Bureau Monitoring Well Construction and Abandonment Guidelines, Revision 1.1, March 2011 (Monitoring Well Guidance)
- List of Chemicals used at Hobbs Generating Station

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this groundwater discharge permit Renewal (Discharge Permit or DP-1620) to the Lea Power Partners, LLC (Permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Ground and Surface Water Protection Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from the Hobbs Generating Station (Facility) in order to protect groundwater and those segments of surface water gaining from groundwater inflow for present and potential future use as domestic and agricultural water supply and other uses, and to protect public health. It is NMED's determination in issuing this Discharge Permit that the Permittee has met the requirements of Subsection C of 20.6.2.3109 NMAC. The Permittee is responsible for complying with the terms and conditions of this Discharge Permit pursuant to Section 20.6.2.3104 NMAC; failure to do so may result in enforcement action by NMED (20.6.2.1220 NMAC).

Described below are the activities that produce the discharge, the location of the discharge, and the quantity, quality, and flow characteristics.

The Facility discharges industrial wastewater at a volume up to 5 million gallons per month (MGM) or 165,000 gallons per day (gpd), on an annual average, from a 600-megawatt, combined cycle power generating station to two double synthetically lined storage impoundments for disposal by evaporation and land application. The industrial wastewater discharged to the impoundments consists of evaporative cooler blowdown, boiler blowdown, reverse osmosis reject water, and filter backwash. From the storage impoundments, the Permittee discharges reclaimed industrial wastewater to approximately 58.62 acres of native cool season and warm season perennial grasses (land application area) using a single center pivot system.

Data collected from on-site monitoring well MW-4A prior to going dry has documented groundwater contamination reporting exceedances of groundwater quality standards for TDS and sulfate according to the criteria of Sections 20.6.2.3101 and 20.6.2.3103 NMAC. This Discharge Permit contains requirements, for the Permittee to conduct a study of the source(s) of groundwater contamination documented by MW-4A and includes contingencies if the Permittee is identified as responsible for or contributing to the groundwater contamination.

The discharge may contain water contaminants or toxic pollutants elevated above the standards of Section 20.6.2.3103 NMAC and is not subject to the exemption at Subsection 20.6.2.3105.A NMAC.

The Facility is located at 98 N. Twombly Lane in Hobbs New Mexico, approximately 10 miles northwest of Hobbs, in Sections 24 and 25, Township 18 South, Range 36 East, in Lea County. A

discharge at the Facility is most likely to affect groundwater at a depth of approximately 50-70 feet and having a pre-discharge total dissolved solids (TDS) concentration of approximately 340 milligrams per liter.

NMED issued the original Discharge Permit to the Permittee on April 2, 2007, and subsequently renewed and modified the Permit on December 19, 2011, and renewed the Permit on July 6, 2017. The application (i.e., discharge plan) associated with this Discharge Permit consists of the materials submitted by Alliant Environmental, LLC, on behalf of the Permittee dated December 21, 2021, and materials contained in the administrative record prior to issuance of this Discharge Permit.

The Permittee shall manage the discharge in accordance with all conditions and requirements of this Discharge Permit.

This Discharge Permit requires an associated Closure Plan, the intent of which it is to prevent the exceedance of the groundwater protection standards of 20.6.2.3103 NMAC after the Facility, or a portion of the Facility, ceases to operate. The Closure Plan shall include a detailed description of all closure and post-closure maintenance and inspection procedures. The Permittee's obligation to implement the Closure Plan and associated permit requirements survives the termination or expiration of this Discharge Permit. The Permittee may implement and complete portions of the Closure Plan prior to the cessation of the operation of the Facility.

This Discharge Permit requires financial assurance requirements associated with closure of the structures associated with this Permit, including a requirement to produce a closure cost estimate intended to sufficiently identify the cost of implementing all aspects of closure as described in the Closure Plan. This Discharge Permit requires the establishment of a financial assurance instrument intended to cover all closure costs as identified in the closure cost estimate. This Discharge Permit requires the maintenance of financial assurance during the term of this Discharge Permit and until successful accomplishment of all closure activities.

NMED reserves the right to require a Discharge Permit modification in the event NMED determines that the Permittee is or may be violating, or is likely to violate in the future, the requirements of 20.6.2 NMAC or the standards of Section 20.6.2.3103 NMAC. NMED reserves this right pursuant to Section 20.6.2.3109 NMAC. An NMED requirement to modify the Discharge Permit may result from a determination by the department that structural controls and/or management practices approved under this Discharge Permit are insufficiently protective of groundwater quality and human health. NMED reserves the right to require the Permittee to implement abatement of water pollution and remediate groundwater quality.

NMED issuance of this Discharge Permit does not relieve the Permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

This Discharge Permit may use the following acronyms and abbreviations.

Abbreviation	Explanation	Abbreviation	Explanation
BOD ₅	biochemical oxygen demand (5-day)	NMED	New Mexico Environment Department
CAP	Corrective Action Plan	NMSA	New Mexico Statutes Annotated
CFR	Code of Federal Regulations	NO ₃ -N	nitrate-nitrogen
CFU	colony forming unit	NTU	nephelometric turbidity units
Cl	chloride	QA/QC	Quality Assurance/Quality Control
EPA	United States Environmental Protection Agency	TDS	total dissolved solids
Gpd	gallons per day	TKN	total Kjeldahl nitrogen
LAA	land application area	total nitrogen	= TKN + NO ₃ -N
LADS	Land Application Data Sheet(s)	TRC	total residual chlorine
mg/L	milligrams per liter	TSS	total suspended solids
mL	milliliters	WQA	New Mexico Water Quality Act
MPN	most probable number	WQCC	Water Quality Control Commission
NMAC	New Mexico Administrative Code	WWTF	Wastewater Treatment Facility

II. FINDINGS

In issuing this Discharge Permit, NMED finds the following.

1. The Permittee is discharging effluent or leachate from the Facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing concentration of 10,000 mg/L or less of TDS, within the meaning of Subsection A of 20.6.2.3101 NMAC, without exceeding standards of 20.6.2.3103 NMAC for any water contaminant.
2. The Permittee is discharging effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit and Sections 20.6.2.3000 through 20.6.2.3114 NMAC.
3. The discharge from the Facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

The Permittee is responsible for ensuring that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein pursuant to 20.6.2.3104 NMAC.

This Discharge Permit authorizes the Permittee to discharge up to 5 MGM (165,000 gpd), on an annual average, of evaporative cooler blowdown, boiler blowdown, reverse osmosis reject and filter backwash industrial wastewater to two double synthetically-lined storage impoundments for disposal by evaporation and land application to approximately 58.62 acres of native cool season and warm season perennial grasses.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection D of 20.6.2.3109 NMAC]

IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

A. OPERATIONAL PLAN

#	Terms and Conditions
1.	The Permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 2 and 4 NMAC. [Subsection C of 20.6.2.3109 NMAC]
2.	The Permittee shall operate in a manner that does not violate the standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC. [20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]

Operating Conditions

#	Terms and Conditions
3.	The Permittee shall ensure adherence to the following general requirements for above-ground use of reclaimed industrial wastewater. a) The Permittee shall install and maintain signs in English and Spanish at all reuse areas such that they are visible and legible for the term of this Discharge Permit. The Permittee shall post signs at the entrance to reuse areas and at other locations where public exposure to reclaimed industrial wastewater may occur. The signs shall state: NOTICE: THIS AREA IS IRRIGATED WITH RECLAIMED WASTEWATER - DO NOT DRINK. AVISO: ESTA ÁREA ESTÁ REGADA CON AGUAS NEGRAS RECOBRADAS - NO

#	Terms and Conditions
	<p>TOMAR. The Permittee may submit alternate wording and/or graphics to NMED for approval.</p> <ul style="list-style-type: none"> b) Reclaimed industrial wastewater systems shall have no direct or indirect cross connections with public water systems or irrigation wells pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC). c) Above-ground use of reclaimed industrial wastewater shall not result in excessive ponding of wastewater and shall not exceed the water consumptive needs of the crop. The Permittee shall not discharge reclaimed industrial wastewater at times when the reuse area is saturated or frozen. d) The Permittee shall confine discharge of reclaimed industrial wastewater to the reuse area. e) The Permittee shall not discharge reclaimed industrial wastewater to crops used for human consumption. f) Water supply wells within 200 feet of a reuse area shall have adequate wellhead construction pursuant to 19.27.4 NMAC. g) Existing and accessible portions of the reclaimed domestic wastewater distribution system (with the exception of application equipment such as sprinklers or pivots) shall be colored purple or clearly labeled as being part of a reclaimed domestic wastewater distribution system. Piping, valves, outlets, and other plumbing fixtures shall be purple pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC) to differentiate piping or fixtures used to convey reclaimed wastewater from those intended for potable or other uses. h) Valves, outlets, and sprinkler heads used in reclaimed wastewater systems shall be accessible only to authorized personnel. <p>The Permittee shall demonstrate adherence to these requirements by submitting documentation consisting of narrative statements and date-stamped photographs as appropriate. The Permittee shall submit the documentation to NMED once during the term of this Discharge Permit in the next required periodic monitoring report after the issuance of the Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1–78, § 74-6–5.D]</p>
4.	<p>The Permittee shall meet the following setbacks, access restrictions and equipment requirements for spray irrigation using reclaimed industrial wastewater.</p> <ul style="list-style-type: none"> a) Maintain a minimum 100-foot setback between any dwellings or occupied establishments and the edge of the reuse area. b) Postpone irrigation using reclaimed industrial wastewater at times when windy conditions may result in drift of reclaimed industrial wastewater outside the reuse area.

#	Terms and Conditions
	<p>c) Restrict access to the reuse area using perimeter fencing with four-strand barbed wire and a locking gate, or other access controls approved by NMED.</p> <p>d) Prohibit public access during times when reclaimed industrial wastewater is being applied to the reuse area.</p> <p>e) Limit the spray irrigation system to low trajectory spray nozzles.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1-78, § 74-6-5.D]</p>
5.	<p>The Permittee shall institute a backflow prevention method to protect wells and public water supply systems from contamination by reclaimed industrial wastewater prior to discharging to the reuse area. Backflow prevention shall be achieved by a total disconnect (physical air gap separation between the discharge pipe and the liquid surface at least twice the diameter of the discharge pipe), or by a reduced pressure principal backflow prevention assembly (RP) installed on the line between the fresh water supply wells or public water supply and the reclaimed industrial wastewater delivery system. The Permittee shall maintain backflow prevention at all times.</p> <p>The Permittee shall have RP devices inspected and tested by a certified backflow prevention assembly tester at the time of installation, repair or relocation and at least on an annual basis thereafter. The backflow prevention assembly tester shall have successfully completed a 40-hour backflow prevention course based on the University of Southern California’s Backflow Prevention Standards and Test Procedures, and obtained certification demonstrating completion. The Permittee shall have all malfunctioning RP devices repaired or replaced within 30 days of discovery. The Permittee shall cease using supply lines associated with the RP device until repair or replacement is complete.</p> <p>The Permittee shall maintain copies of the inspection and maintenance records and test results for each RP device associated with the backflow prevention program at a location available for inspection by NMED.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>
6.	<p>The Permittee shall maintain fences around the Facility to restrict access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. The Permittee shall maintain the fences to serve the stated purpose throughout the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
7.	<p>The Permittee shall maintain signs indicating that the wastewater at the Facility is not potable. The Permittee shall post signs at the Facility entrance and other areas where there is potential for public contact with wastewater. The Permittee shall print signs in</p>

#	Terms and Conditions
	<p>English and Spanish and shall ensure the signs remain visible and legible for the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
8.	<p>The Permittee shall maintain the impoundment liners to avoid conditions that could affect the liner or the structural integrity of the impoundments. Characterization of such conditions may include the following:</p> <ul style="list-style-type: none">• erosion damage;• animal burrows or other damage;• the presence of vegetation including aquatic plants, weeds, woody shrubs or trees growing within five feet of the top inside edge of a sub-grade impoundment, within five feet of the toe of the outside berm of an above-grade impoundment, or within the impoundment itself;• the presence of large debris or large quantities of debris in the impoundment;• evidence of seepage; or• evidence of berm subsidence. <p>The Permittee shall routinely control vegetation growing around the impoundments by mechanical removal that is protective of the impoundment liner.</p> <p>The Permittee shall visually inspect the impoundments and surrounding berms on a monthly basis to ensure proper maintenance. In the event that an inspection reveals any evidence of damage that threatens the structural integrity of an impoundment berm or liner, or that may result in an unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>The Permittee shall create and maintain a log of all impoundment inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
9.	<p>The Permittee shall preserve a minimum of two feet of freeboard, i.e., the liquid level in the impoundments and the elevation of the lowest-most top of the impoundment liner.</p> <p>In the event that the Permittee determines that it cannot preserve two feet of freeboard in an impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

#	Terms and Conditions
10.	<p>The Permittee shall only add the chemicals listed in the renewal application submitted on December 14, 2021, under Appendix H: Estimated Usage and SDS of Chemicals used in the Water Treatment Facility, Cooling Towers, and HRSG Boiler Water to water that the Permittee reasonably expects to enter the storage impoundments.</p> <p>In the event that the Permittee intends to replace a product with a similar product, intended for the same use, for which a safety data sheet (SDS) was not previously submitted during the term of this Discharge Permit, the Permittee shall submit the product's SDS to NMED within 30 days of knowledge of the product's use.</p> <p>In the event that the Permittee intends to introduce a new product into the treatment process, for which an SDS was not previously submitted during the term of this Discharge Permit, the Permittee shall submit the product's SDS for approval by NMED within 60 days prior to use.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
11.	<p>Prior to cleaning operations of the main boiler, the Permittee shall submit SDSs and amounts the Permittee will add for all chemicals and products the Permittee will use that the Permittee reasonably expects to enter the storage impoundments.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

B. MONITORING AND REPORTING

#	Terms and Conditions
12.	<p>The Permittee shall conduct the monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
13.	<p>METHODOLOGY – Unless otherwise specified by this Discharge Permit, or approved in writing by NMED, the Permittee shall use sampling and analytical techniques that conform with the references listed in Subsection B of 20.6.2.3107 NMAC.</p> <p>[Subsection B of 20.6.2.3107 NMAC]</p>

Due Dates for Monitoring Reports

#	Terms and Conditions
14.	Semi-annual monitoring - The Permittee shall perform monitoring and other Permit required actions during the following periods and shall submit semi-annual reports to NMED by the following due dates: <ul style="list-style-type: none"> • January 1st through June 30th – due by August 1st; and • July 1st through December 31st – due by February 1st. <p>[Subsection A of 20.6.2.3107 NMAC]</p>

Monitoring Actions with Implementation Deadlines

#	Terms and Conditions
15.	The Permittee shall submit within 60 days following the issuance date of this Discharge Permit (by DATE) a proposal for the repair of MW-4A to NMED for review and approval. [Subsection A of 20.6.2.3107 NMAC]
16.	In the event that MW-4A is not successfully repaired, the Permittee shall submit within 60 days following the determination in Condition 15, a proposal for the replacement of MW-4A with MW-4B to NMED for review and approval. The proposal shall include, at a minimum, the following information: <ol style="list-style-type: none"> a) A map showing the proposed location of the monitoring well in relation to the boundary of the source it is intended to monitor. b) A written description of the specific location proposed for the monitoring well including the distance (in feet) and direction of the monitoring well from the edge of the source it is intended to monitor. Examples include: 35 feet north-northwest of the northern berm of the synthetically lined impoundment; 45 feet due south of the leachfield; and 30 feet southeast of the reuse area 150 degrees from north. c) Justification for a new location of monitor well MW-4B. d) A statement describing the groundwater flow direction beneath the Facility, and documentation and/or data supporting the determination. <p>The Permittee must have NMED’s approval of all monitoring well locations prior to their installation.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
17.	Within 60 days of NMED approval of the MW-4B replacement proposal, the Permittee shall install the following new monitoring well. <ol style="list-style-type: none"> a) One monitoring well (MW-4B) located 20 to 50 feet hydrologically downgradient of

#	Terms and Conditions
	<p>the land application area.</p> <p>The Permittee shall complete the well in accordance with the attached Monitoring Well Guidance.</p> <p>Unless otherwise noted in this Discharge Permit, the requirement to install a monitoring well downgradient of a source is <u>not</u> contingent upon construction of the Facility, or discharge of wastewater from the Facility.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
18.	<p>In the event that MW-4A is not successfully repaired, the Permittee shall properly plug and abandon the monitoring well:</p> <p>The Permittee shall abandon the monitoring well in accordance with the attachment titled <i>New Mexico Environment Department Ground Water Quality Bureau Monitoring Well Construction and Abandonment Guidelines</i>, Revision 1.1, March 2011, and all applicable local, state, and federal regulations, including 19.27.4 NMAC.</p> <p>The Permittee shall submit documentation describing the well abandonment procedures in accordance with the above-mentioned Guidelines. The Permittee shall submit the well abandonment documentation to NMED within 60 days of completion of well plugging activities.</p> <p>[Subsection A of 20.6.2.3107 NMAC, 19.27.4 NMAC]</p>
19.	<p>Within 160 days of repair of MW-4A or installation of MW-4B, the Permittee shall perform a professional survey of all groundwater monitoring wells approved by NMED for Discharge Permit monitoring purposes. The survey shall be tied or referenced to a U.S. Geological Survey (USGS) or other permanent benchmark. Survey data shall include northing, easting and elevation to the nearest one-hundredth of a foot or shall be in accordance with the "Minimum Standards for Surveying in New Mexico" (12.8.2 NMAC). The survey shall bear the seal and signature of a licensed New Mexico professional surveyor (pursuant to the New Mexico Engineering and Surveying Practice Act and the rules promulgated under that authority).</p> <p>The Permittee shall utilize the survey to establish an elevation at the top-of-casing, with a permanent marking indicating the point of elevation.</p> <p>Depth-to-most-shallow groundwater shall be measured to the nearest one-hundredth of a foot in all surveyed wells [and referenced to mean sea level], and the data shall be used to develop a groundwater elevation contour, i.e., potentiometric surface, map showing the location of all monitoring wells and the direction and gradient of groundwater flow</p>

#	Terms and Conditions
	<p>in the uppermost aquifer below the Facility. The Permittee shall submit the data and groundwater elevation contour map to NMED within 30 days of survey completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p>
20.	<p>The Permittee shall sample reclaimed industrial wastewater for the presence of perfluorinated chemicals (PFCs).</p> <p>Within 2.5 years of the issuance date of this Discharge Permit (by DATE), the Permittee shall collect one grab sample from each impoundment that is representative of the discharge contained therein. The Permittee shall analyze the sample for the following PFCs:</p> <ul style="list-style-type: none"> • perfluorohexane sulfonic acid (PFHxS) (CAS 355-46-4) • perfluorooctane sulfonate (PFOS) (CAS 1763-23-1) • perfluorooctanoic acid (PFOA) (CAS 335-67-1) <p>The Permittee shall properly collect, prepare, preserve, transport, and analyze the sample in accordance with ASTM D7979-17, or an equivalent method that uses liquid chromatography and tandem mass spectrometry (LC/MS/MS). The reporting limit shall be low enough to identify whether the combined concentration of the perfluorinated chemicals is less than the Tap Water Screening Level identified in the <i>NMED Risk Assessment Guidance for Site Assessments and Investigations</i>, Table A-1 available on the NMED Hazardous Waste Bureau’s website under Guidance Documents. The Permittee shall take appropriate measures to avoid cross contamination while collecting and transporting the sample. The selected laboratory should be able to provide guidance that ensures sample integrity. The Permittee shall submit a copy of the laboratory report, including analytical results, the QA/QC summary, and the Chain of Custody to NMED within 30 days of laboratory report receipt.</p> <p>[Subsection H of 20.6.2.3109 NMAC, Subsection A of 20.6.2.3107 NMAC]</p>

Groundwater Monitoring Conditions

#	Terms and Conditions
21.	<p>The Permittee shall perform semi-annual groundwater sampling in the following groundwater monitoring wells and analyze the samples for TKN, NO₃-N, TDS, Cl and SO₄.</p> <ol style="list-style-type: none"> a) MW-1, located hydrologically upgradient of the storage impoundments. b) MW-2, located hydrologically downgradient of the western synthetically lined impoundment (West Pond). c) MW-3, located hydrologically downgradient of the eastern synthetically lined impoundment (East Pond).

#	Terms and Conditions
	<p>d) MW-4A or MW-4B, located hydrologically downgradient of the land application area.</p> <p>The Permittee shall perform groundwater sample collection, preservation, transport, and analysis according to the following procedures.</p> <ul style="list-style-type: none"> a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot. b) Purge three well volumes of water from the well prior to sample collection. c) Obtain samples from the well for analysis. d) Properly prepare, preserve, and transport samples. e) Analyze samples in accordance with the methods authorized in this Discharge Permit. <p>The Permittee shall submit the depth-to-most-shallow groundwater measurements and the laboratory analytical data results including the laboratory QA/QC summary report for each well, and a Facility layout map showing the location and number of each well to NMED in the semi-annual monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
22.	<p>In addition to, and as part of the groundwater sampling events as required by this Discharge Permit, the Permittee shall perform two groundwater sampling events, one in 2025 and one in 2027, and analyze the samples for all major cations and anions and contaminants listed under Section 20.6.2.3103 NMAC except for radioactivity (combined radium-226 and radium-228) and polychlorinated biphenyls.</p> <p>The permittee shall sample the following.</p> <ul style="list-style-type: none"> a) MW-1, located hydrologically upgradient of the storage impoundments. b) MW-2, located hydrologically downgradient of the western synthetically lined impoundment (West Pond). c) MW-3, located hydrologically downgradient of the eastern synthetically lined impoundment (East Pond). d) MW-4A or MW-4B, located hydrologically downgradient of the land application area. <p>The Permittee shall perform groundwater sample collection, preservation, transport, and analysis according to the following procedures.</p> <ul style="list-style-type: none"> a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot. b) Purge three well volumes of water from the well prior to sample collection. c) Obtain samples from the well for analysis. d) Properly prepare, preserve, and transport samples. e) Analyze samples in accordance with the methods authorized in this Discharge Permit. <p>The Permittee shall submit the depth-to-most-shallow groundwater measurements and the laboratory analytical data results including the laboratory QA/QC summary report for</p>

#	Terms and Conditions
	<p>each well, and a Facility layout map showing the location and number of each well to NMED in the semi-annual monitoring reports due by August 1st of 2025 and 2027.</p> <p>(Subsection A of 20.6.2.3107 NMAC)</p>
23.	<p>The Permittee shall develop a groundwater elevation contour map, i.e., potentiometric surface map, on a semi-annual basis using the top of casing elevation data from the monitoring well survey and the most recent depth-to-most-shallow groundwater measurements, referenced to mean sea level, obtained during the groundwater sampling required by this Discharge Permit.</p> <p>The groundwater elevation contour map shall depict the groundwater flow direction based on the groundwater elevation contours. The Permittee shall estimate groundwater elevations between monitoring well locations using common interpolation methods. The Permittee shall use a contour interval appropriate to the data but shall not be greater than two feet. Groundwater elevation contour maps shall use arrows to depict the groundwater flow direction based on the orientation of the groundwater elevation contours and shall locate and identify each monitoring well and contaminant source.</p> <p>The Permittee shall submit to NMED a groundwater elevation contour map in the semi-annual monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
24.	<p>NMED shall have the option to perform downhole inspections of all groundwater monitoring wells identified in this Discharge Permit. NMED shall establish the inspection date and notify the Permittee. The Permittee shall remove any existing dedicated pumps at least 48 hours prior to NMED inspection to allow adequate settling time of sediment agitated from pump removal.</p> <p>Should the Permittee decide to install a pump in a monitoring well without a dedicated pump, the Permittee shall notify NMED at least 90 days prior to pump installation so that NMED can schedule a downhole well inspection(s) prior to pump placement.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>

Facility Monitoring Conditions

#	Terms and Conditions
25.	<p>The Permittee shall measure the total monthly volume and calculate the daily average volume of the following:</p>

#	Terms and Conditions
	<p>wastewater discharged from the generating station to each of the synthetically lined impoundments,</p> <ul style="list-style-type: none"> • wastewater discharged from the synthetically lined impoundments to the land application area, and • supplemental groundwater pumped from the private irrigation well and discharged to the land application area. <p>The Permittee shall measure discharge volumes with totalizing flow meters and submit the totalized average daily volumes for each month to NMED in the semi-annual monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
26.	<p>All flow meters shall be capable of having their accuracy verified under working (i.e., real-time in-the-field) conditions. The Permittee shall develop a field verification method for each flow meter and shall utilize that method to check the accuracy of each respective meter. The Permittee shall perform field calibrations, at a minimum, on an annual basis. The Permittee shall also perform field calibrations upon repair or replacement of a flow measurement device.</p> <p>The Permittee shall calibrate each flow meter to its manufacturer’s recommended specification which shall be no less accurate than plus or minus 10 percent of actual flow, as measured under field conditions. An individual knowledgeable in flow measurement shall perform field calibration and the installation/operation of the device in use. The Permittee shall prepare a flow meter calibration report for each flow measurement device calibration event. The flow meter calibration report shall include the following information.</p> <ol style="list-style-type: none"> a) The location and meter identification. b) The method of flow meter field calibration employed. c) The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check. d) The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter. e) Any flow meter repairs made during the previous year or during field calibration. f) The name of the individual performing the calibration and the date of the calibration. <p>The Permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during Facility inspections.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>

#	Terms and Conditions
27.	<p>The Permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. The Permittee shall maintain a log of the inspections that includes a date of the inspection, findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the Permittee shall repair or replace the meter within 30 days of discovery. For <i>repaired</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
28.	<p>The Permittee shall collect a composite wastewater sample on a semi-annual basis (once every six months) from each of the evaporation impoundments (i.e., West Pond and East Pond). The composite sample shall consist of a minimum of six equal aliquots collected equidistantly around the entire perimeter of the evaporative impoundment and thoroughly mixed. The Permittee shall analyze the composite sample for:</p> <ul style="list-style-type: none"> • pH; • TKN; • NO₃-N; • TDS; • Cl; and • SO₄. <p>The Permittee shall ensure the sample is properly prepared, preserved, transported, and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, to NMED in the semi-monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
29.	<p>Twice during the term of this Discharge Permit (2025 and 2027), the Permittee shall collect a composite sample (except as noted for pH) of industrial wastewater from each impoundment and analyze the sample for the following inorganic contaminants (dissolved fraction, except as noted):</p> <ul style="list-style-type: none"> • aluminum (CAS 7429-90-5) • lead (CAS 7439-92-1)

#	Terms and Conditions
	<ul style="list-style-type: none"> • antimony (CAS 7440-36-0) • arsenic (CAS 7440-38-2) • barium (CAS 7440-39-3) • beryllium (CAS 7440-41-7) • boron (CAS 7440-42-8) • cadmium (CAS 7440-43-9) • chromium (CAS 7440-47-3) • cobalt (CAS 7440-48-4) • copper (CAS 7440-50-8) • cyanide CAS 57-12-5) • fluoride (CAS 16984-48-8) • iron (CAS 7439-89-6) • manganese (CAS 7439-96-5) • molybdenum (CAS 7439-98-7) • total mercury (nonfiltered) (CAS 7439-97-6) • pH (instantaneous) • nickel (CAS 7440-02-0) • selenium (CAS 7782-49-2) • silver (CAS 7440-224) • sulfate (CAS 14808-79-8) • thallium (CAS 7440-28-0) • uranium (CAS 7440-61-1) • zinc (CAS 7440-66-6) <p>The composite sample shall consist of a minimum of six equal aliquots collected equidistantly around the entire perimeter of the evaporative impoundment and thoroughly mixed.</p> <p>The Permittee shall properly collect, prepare, preserve, transport and analyze the samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall analyze the sample using methods with reporting limits that are less than the corresponding numerical groundwater standards identified in 20.6.2.3103 NMAC.</p> <p>The Permittee shall submit a summary of measured concentrations compared with the corresponding groundwater standards, a copy of the laboratory report including the laboratory analytical data results, the QA/QC summary and the Chain of Custody, to NMED in the monitoring reports due by August 1st in 2025 and 2027.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
30.	<p>Twice during the term of this Discharge Permit (2025 and 2027) the Permittee shall collect a composite sample of industrial wastewater from each impoundment and analyze the non-filtered sample for the following organic contaminants:</p> <ul style="list-style-type: none"> • atrazine (CAS 1912-24-9) • benzene (CAS 71-43-2) • benzo-a-pyrene (CAS 50-32-8) • carbon tetrachloride (CAS 56-23-5) • chloroform (CAS 67-66-3) • 1,2-dichlorobenzene (CAS 95-50-1) • 1,4-dichlorobenzene (CAS 106-46-7) • methylene chloride (CAS 75-09-) • <u>PAHs</u>: total naphthalene (CAS 91-20-3) plus monomethylnaphthalenes • phenols • pentachlorophenol (CAS 87-86-5) • toluene (CAS 108-88-3) • styrene (CAS 100-42-5)

#	Terms and Conditions
	<ul style="list-style-type: none"> • 1,1-dichloroethane (CAS 75-34-3) • 1,2-dichloroethane (EDC, CAS 107-06-2) • 1,1-dichloroethene (1,1-DCE, CAS 75-35-4) • cis-1,2-dichloroethene (CAS 156-59-2) • trans-1,2-dichloroethene (CAS 156-60-5) • 1,2-dichloropropane (PDC, CAS 78-87-5) • 1,4-dioxane (CAS 123-91-1) (using EPA Method 8270D- SIM) • ethylbenzene (CAS 100-41-4) • ethylene dibromide (EDB, CAS 106-93-4) • 1,1,2,2-tetrachloroethane (CAS 79-34-5) • tetrachloroethene (PCE, CAS 127-18-4) • 1,2,4-trichlorobenzene (CAS 120-82-1) • 1,1,1-trichloroethane (1,1,1-TCA, CAS 71-55-6) • 1,1,2-trichloroethane (CAS 79-00-5) • trichloroethene (TCE, CAS 79-01-6) • vinyl chloride (CAS 75-01-4) • total xylenes (CAS 1330-20-7) <p>The composite sample shall consist of a minimum of six equal aliquots collected equidistantly around the entire perimeter of the evaporative impoundment and thoroughly mixed.</p> <p>The Permittee shall properly collect, prepare, preserve, transport, and analyze the samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall analyze samples using methods with reporting limits that are less than the corresponding numerical groundwater standards identified in 20.6.2.3103 NMAC. The reporting limit for 1,4-dioxane shall be less than the Tap Water Screening Level for 1,4-dioxane identified in the <i>NMED Risk Assessment Guidance for Site Assessments and Investigations</i>, Table A-1 (available on the NMED Hazardous Waste Bureau’s website under Guidance Documents).</p> <p>If the results of two consecutive sampling events indicate no detection of 1,4-dioxane above the reporting limit, the Permittee may request to reduce the sampling frequency.</p> <p>The Permittee shall submit a summary of measured concentrations compared with the corresponding groundwater standards, and a copy of the laboratory report including the laboratory analytical data results, the QA/QC summary and the Chain of Custody to NMED in the monitoring reports due by August 1st 2025 and 2027.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>

#	Terms and Conditions
31.	<p>The Permittee shall inspect the two leak detection sumps monthly for liquid. If liquid is present in the leak detection sumps, the Permittee shall sample the liquid within 15 days and analyze the sample(s) for TKN, NO₃-N, TDS, Cl, SO₄, and pH.</p> <p>In the event that the Permittee determines that water in the leak detection sump(s) is similar to the wastewater in the impoundment(s) and indicative of a leak in the impoundment's liner, the Permittee shall implement the related Contingency Plan requirement set forth in this Discharge Permit.</p> <p>The Permittee shall maintain a log of the leak detection sumps inspections which identifies the date of the inspection, all findings, the laboratory analytical data results including the QA/QC summary, and the name of the person responsible for the inspection.</p> <p>The Permittee shall submit the inspection records, findings, and analytical results to NMED in the semi-annual monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

C. ADDITIONAL STUDIES REQUIRED

#	Terms and Conditions
32.	<p>The Permittee shall complete and submit a study to NMED that includes an investigation of the impacts of the current and past wastewater disposal methods on the soil and groundwater at the facility. The Permittee shall complete the study using standard environmental site investigation methodologies and practices to document existing soil and groundwater conditions including the sources of the groundwater contamination found in MW-4A. The study shall bear the seal of a New Mexico licensed professional engineer. The Permittee shall submit the study to NMED within 2 years of issuance of this Discharge Permit (by date).</p> <p>Based on the results of the study, if NMED concludes that the current and past disposal practices at the Facility have been protective of groundwater and have not contributed to existing contamination, the conditions of this Discharge Permit shall continue to be in effect as written.</p> <p>Based on the results of the study, if NMED concludes that the practices at the Facility are not protective of groundwater and are contributing to groundwater contamination, NMED will notify the Permittee of the determination in a letter setting the Date of Determination. The Permittee shall submit an application for modification to NMED that includes an alternative disposal method within one year of the Date of Determination and</p>

#	Terms and Conditions
	<p>concurrently limit discharge to the land application area to the extent possible while maintaining two feet of freeboard in the storage impoundments. Examples of alternative disposal practices include the addition of treatment for the wastewater prior to discharging to the land application area or construction of adequate synthetically lined storage impoundments for complete disposal by evaporation.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>

D. CONTINGENCY PLAN

#	Terms and Conditions
33.	<p>In the event that groundwater monitoring indicates that groundwater exceeds a standard identified in Section 20.6.2.3103 NMAC, the Permittee shall collect a confirmatory sample from the monitoring well within 15 days of receipt of the initial sampling results to confirm the initial sampling results.</p> <p>Within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule. The Permittee shall implement the CAP as approved by NMED.</p> <p>Once this groundwater exceedance response condition is invoked whether during the term of this Discharge Permit or after the term of this Discharge Permit and prior to the completion of the Discharge Permit closure plan requirements, this condition shall apply until the Permittee has fulfilled the requirements of this condition and groundwater monitoring confirms for a minimum of eight (8) consecutive quarterly samples that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC.</p> <p>Violation of the groundwater standard beyond 180 days after the confirmation of groundwater contamination may cause NMED to require the Permittee to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101, Section 20.6.2.4103, Subsections C and E of 20.6.2.4106, Section 20.6.2.4107, Section 20.6.2.4108 and Section 20.6.2.4112 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>
34.	<p>In the event that information available to NMED indicates that a well is not constructed in a manner consistent with the attached Monitoring Well Guidance; contains insufficient water to effectively monitor groundwater quality; or is otherwise not completed in a manner that is protective of groundwater quality, the Permittee shall install a replacement well(s) within 120 days following notification from NMED.</p>

#	Terms and Conditions
	<p>The Permittee shall survey the replacement monitoring well(s) within 30 days following well completion.</p> <p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the Monitoring Well Guidance. The Permittee shall submit well construction and lithologic logs [survey data and a groundwater elevation contour map] to NMED within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
35.	<p>In the event that groundwater flow information obtained pursuant to this Discharge Permit indicates that a monitoring well is not appropriately located, e.g., hydrologically downgradient of the discharge location it is intended to monitor, the Permittee shall install a replacement well within 120 days following notification from NMED. The Permittee shall survey the replacement monitoring well within 30 days following well completion.</p> <p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the attached Monitoring Well Guidance. The Permittee shall submit construction and lithologic logs, survey data and a groundwater elevation contour map within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
36.	<p>In the event that the laboratory analytical data results of the liquid present in the leak detection sump indicates that the chemical content of the liquid is consistent with the contents of the evaporative impoundment, the Permittee shall submit a CAP to NMED</p>

#	Terms and Conditions
	<p>which evaluates the primary liner leakage rate and proposes options for stopping or reducing leakage. The Permittee shall submit the CAP to NMED for approval within 60 days of the receipt of the analytical results.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
37.	<p>In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of an impoundment or liner or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a CAP to NMED for approval. The Permittee shall submit the CAP to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
38.	<p>In the event that an impoundment cannot preserve a minimum of two feet of freeboard, the Permittee shall take actions to restore the required freeboard as authorized by this Discharge Permit and all applicable local, state, and federal regulations.</p> <p>In the event that two feet of freeboard cannot be restored within a period of 72 hours following discovery, the Permittee shall propose actions to restore two feet of freeboard by submitting a short-term CAP to NMED for approval. Examples of short-term corrective actions include the pumping and hauling of excess wastewater from the impoundment or reducing the volume of wastewater discharged to the impoundment. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall submit the CAP within 15 days following the date the Permittee or the NMED discover the exceedance. The Permittee shall implement the CAP following NMED approval.</p> <p>In the event that the short-term corrective actions fail to restore two feet of freeboard, the Permittee shall submit to NMED a proposal for permanent corrective actions in a long-term CAP. The Permittee shall submit the long-term CAP within 90 days following failure of the short-term CAP. Examples corrective actions include the installation of an additional storage impoundment or a significant and permanent reduction in the volume of wastewater discharged to the impoundment. The Permittee shall ensure the long-term CAP includes a schedule for completion of corrective actions. The Permittee shall implement the CAP following NMED approval.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

#	Terms and Conditions
39.	<p>In the event that a release occurs that is not authorized under this Discharge Permit (commonly known as a “spill”), the Permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below. A release is defined as such quantity as may with reasonable probability injure or be detrimental to human health, animal or plant life, or property, or unreasonably interfere with the public welfare or the use of property.</p> <p>Within <u>24 hours</u> following discovery of the unauthorized discharge, the Permittee shall verbally notify NMED and provide the following information.</p> <ul style="list-style-type: none">a) The name, address, and telephone number of the person or persons in charge of the Facility, as well as of the owner and/or operator of the Facility.b) The name and address of the Facility.c) The date, time, location, and duration of the unauthorized discharge.d) The source and cause of unauthorized discharge.e) A description of the unauthorized discharge, including its estimated chemical composition.f) The estimated volume of the unauthorized discharge.g) Any actions taken to mitigate immediate damage from the unauthorized discharge. <p>Within <u>one week</u> following discovery of the unauthorized discharge, the Permittee shall submit written notification to NMED providing the information listed above and any pertinent updates.</p> <p>Within <u>15 days</u> following discovery of the unauthorized discharge, the Permittee shall submit a CAP to NMED describing any corrective actions previously taken and corrective actions to be taken relative to the unauthorized discharge. The CAP shall include the following information.</p> <ul style="list-style-type: none">a) A description of proposed actions to mitigate damage from the unauthorized discharge.b) A description of proposed actions to prevent future unauthorized discharges of this nature.c) A schedule for completion of proposed actions. <p>In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, NMED may require the Permittee to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC.</p>

#	Terms and Conditions
	<p>The Permittee shall not construe anything in this condition as relieving them of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC.</p> <p>[20.6.2.1203 NMAC]</p>
40.	<p>In the event that NMED or the Permittee identifies any failures of the discharge plan, i.e., the application, or this Discharge Permit not specifically noted herein, NMED may require the Permittee to submit a CAP and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a discharge permit modification to achieve compliance with 20.6.2 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>

E. CLOSURE PLAN

Closure Actions with Implementation Deadlines

#	Terms and Conditions
41.	<p>Within nine (9) months of the issuance date of this Discharge Permit (by DATE), the Permittee shall submit a detailed closure plan for NMED’s approval to prevent the exceedance of standards of 20.6.2.3103 NMAC in groundwater after the cessation of operation. The closure plan shall include at least a 30% level of design, a description of closure measures, maintenance and monitoring plans, post-closure maintenance and monitoring plans, and other measures necessary to prevent or abate such contamination, e.g., a corrective action plan.</p> <p>The Permittee shall ensure that the closure plan is sufficiently detailed to address the steps necessary to close the facility, associated impoundments, irrigation infrastructure, and any other wastewater related infrastructure. Further, the detailed closure plan shall address sludge de-watering (as necessary), characterization of wastes to be disposed on-site and/or off-site, restoration of vegetation, the plugging and abandonment of monitoring wells, all post-closure activities, and ongoing maintenance for all impoundments, irrigation infrastructure, and any other wastewater related infrastructure.</p> <p>The Permittee shall ensure, as necessary, that the closure plan addresses all necessary corrective actions, that at a minimum addresses actions to delineate the nature and extent of any groundwater contamination, contaminant source control measures, and any actions to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101 as approved by NMED.</p> <p>The Permittee shall ensure that the closure plan addresses post-closure care, including the continued groundwater monitoring required under the Discharge Permit. NMED considers all closure and post-closure activities to constitute “complete closure.”</p>

#	Terms and Conditions
	<p>The Permittee shall ensure the closure plan has sufficient detail to estimate the cost of complete closure of all wastewater related infrastructure, post-closure monitoring, and all necessary corrective actions for the purpose of establishing and maintaining financial assurance. The detailed closure plan shall provide sufficient detail to estimate the cost of operation and maintenance of the groundwater monitoring system. Inherent in this detail is an estimate of the time (after the cessation of Facility operation) that the groundwater monitoring system will have to remain in place and in operation, i.e., until WQCC groundwater standards have been met for at least eight consecutive quarters.</p> <p>[Subsection A of 20.6.2.3107]</p>
42.	<p>Within 90 days from the date of NMED's approval of the closure plan, the Permittee shall submit a detailed cost estimate (Estimate) for NMED's approval based on the detailed closure plan for complete closure required by Condition 40. The Estimate shall be based on the cost of hiring a third party to conduct complete closure. The Estimate shall include direct costs associated with third-party implementation of the closure plan, contingency costs in the amount of 15 percent of the direct costs, the cost of an independent project manager and contract administration, and NMED oversight and administration costs, including indirect costs. The Estimate shall forecast the worst-case scenario for complete closure over the five-year period of this Discharge Permit; if a new permit is not issued after five years, the Estimate for the worst-case scenario shall be updated annually each year after five years and any financial assurance shall be adjusted accordingly.</p> <p>The Permittee shall adjust the Estimate for inflation over the five-year period for complete closure and shall project the amount needed for each of the five years for the worst-case scenario for all activities included in complete closure.</p> <p>[Subsection A of 20.6.2.3107]</p>
43.	<p>Within 90 days from the date of NMED's approval of the closure cost estimate (Estimate), the Permittee shall submit to NMED for approval its proposed financial assurance instrument(s) that meets the requirements below.</p> <ul style="list-style-type: none">a) The amount of financial assurance shall be sufficient to cover the cost of implementing complete closure as described in the closure plan and the Estimate required by Conditions 40 and 41 of this Discharge Permit. The Permittee shall not propose any form of self-guarantee. The financial assurance instrument(s) shall ensure that funds will be available to implement complete closure if at any time the Permittee is unable, unwilling, or otherwise fails to implement any portion of the closure plan as required by this Discharge Permit. If the financial assurance instrument(s) entails incremental costs of maintaining the instrument(s), i.e., costs for a trustee, the Permittee shall increase the amount of

#	Terms and Conditions
	<p>the financial assurance to include all such costs.</p> <ul style="list-style-type: none">b) The Permittee shall name NMED as the sole beneficiary in each financial assurance instrument(s).c) The financial assurance instrument(s) shall include a method for adjustments due to changes in inflation, new technologies, and NMED approved revisions to the closure plan based on continued investigations or other information and shall be adjusted no less frequently than every five years such that, at all times, the amount of financial assurance provided by the Permittee shall be sufficient to perform complete closure at any time during the following five years from the update.d) Within 30 days after NMED approves the draft financial assurance instrument(s) the Permittee shall execute the financial assurance instrument and submit it to NMED for final acceptance.e) Within 30 days of the implementation of the financial assurance instrument(s), the Permittee shall establish a trust to receive and disburse funds, which may arise as the result of forfeiture of financial assurance. The trust shall name NMED as the beneficiary. The trust agreement shall be in a form satisfactory to the State Board of Finance and shall be subject to approval by the Governor pursuant to NMSA 1978, § 46-4-1 through 9. The Permittee shall maintain the trust until complete closure has occurred and NMED terminates any existing discharge permit in effect at the time. Upon forfeiture of financial assurance, the forfeited amount shall transfer from the financial assurance instrument into the trust for use by NMED or a third-party for any activities or costs related to complete closure.f) The Permittee may propose alternative financial assurance instrument(s) from time to time subject to NMED's written approval and acceptance. The Permittee shall not replace any approved financial assurance instrument(s) without NMED's written approval.g) Unless released by NMED in writing, the financial assurance instrument(s) shall remain in effect until complete closure and final termination of this Discharge Permit and shall remain in place at all times, including lapses in Discharge Permit coverage, late Discharge Permit renewal, or temporary shutdown of facilities covered under this Discharge Permit.h) Should circumstances warrant more frequent adjustments than provided for in the approved financial assurance instrument(s), NMED may require them in writing and the Permittee shall make the adjustment within 180 days.i) No more frequently than once every 12 months, the Permittee may request that NMED review remaining activities required for complete closure, including alternate closure activities that NMED has approved. The Permittee's request for review shall describe the activities that have been completed and shall contain an updated Estimate for all remaining complete closure activities. If NMED approves the Permittee's description of activities that have been

#	Terms and Conditions
	<p>completed, the remaining activities of complete closure, and the Estimate for remaining complete closure activities, NMED will notify the Permittee of appropriate adjustments that the Permittee may make to the amount of financial assurance.</p> <p>When the WQCC revises the financial assurance regulations and those regulations become effective, the Permittee shall evaluate and, if necessary, revise the financial assurance instrument to comply with the revised WQCC regulations.</p> <p>[Subsection A of 20.6.2.3107]</p>
44.	<p>The Permittee shall adhere to the following stipulations for cancellation, non-renewal, forfeiture, or release of the financial assurance instrument(s).</p> <p>a) Cancellation or Non-renewal: Each financial assurance instrument shall require the financial assurance provider to give at least 120 days written notice to NMED and the Permittee prior to cancellation or non-renewal of the financial assurance instrument. If NMED receives notice of cancellation or non-renewal from a financial assurance provider, the Permittee shall propose an alternate financial assurance mechanism to NMED within 30 days of the notice. If NMED approves the alternate financial assurance mechanism, the Permittee shall execute it and submit it to NMED for final acceptance within 30 days of NMED approval. If the Permittee fails to obtain alternate financial assurance acceptable to NMED within 30 days of NMED approval, the current financial assurance shall be subject to forfeiture.</p> <p>b) Forfeiture: If NMED determines that implementation of all or any part of complete closure is required and that the Permittee is unable or unwilling or will otherwise fail to conduct all or any part of complete closure as required by this Discharge Permit, then NMED may proceed with forfeiture of all or part of the financial assurance.</p> <p>Prior to beginning a forfeiture proceeding, NMED will provide written notice by certified mail to the Permittee and to all financial assurance providers, if applicable. NMED's notice will inform the parties of the determination to forfeit all or a portion of the financial assurance. If NMED's access to the financial assurance is threatened due to time constraints, NMED may begin a forfeiture proceeding and provide written notice contemporaneously with that proceeding. NMED's written notice will state the reasons for the forfeiture and the amount to be forfeited.</p> <p>The forfeited amount shall be based on the total cost of performing complete</p>

#	Terms and Conditions
	<p>closure in accordance with this Discharge Permit and all applicable laws and regulations. NMED will also advise the Permittee and all financial assurance providers, if applicable, of the conditions under which forfeiture may be avoided. Such conditions may include an agreement that the Permittee, a financial assurance provider, or an NMED-approved third party, will perform complete closure in accordance with this Discharge Permit and all applicable laws and regulations, and the entity has demonstrated it has the financial ability and technical qualifications to do so.</p> <p>All financial assurance forfeited shall become immediately payable to the trust or as otherwise provided in the NMED-approved instrument. NMED or a third-party will utilize forfeited funds to perform complete closure. If the forfeited amount is insufficient, the Permittee shall be liable for the remaining costs. If the amount forfeited is more than necessary to complete closure, NMED will refund the excess amount to the entity from whom it was collected.</p> <p>c) Release: NMED will release or modify the financial assurance instrument when NMED determines that all activities of complete closure have been performed according to the closure plan requirements of this Discharge Permit and the Discharge Permit has been terminated.</p> <p>[Subsection A of 20.6.2.3107]</p>

Permanent Facility Closure Conditions

#	Terms and Conditions
45.	<p>The Permittee shall perform the following closure measures in the event the Facility, or a component thereof, is proposed to be permanently closed.</p> <p>Within <u>60 days</u> of ceasing to discharge to the impoundments, the Permittee shall plug the impoundment influent lines so that a discharge can no longer occur.</p> <p>Within <u>60 days</u> of ceasing to discharge to the impoundments, the Permittee shall discharge wastewater from the impoundments and any other wastewater system component to the land application area. The Permittee shall not discharge accumulated solids (sludge) from the impoundment to the land application area.</p> <p>Within <u>one year</u> following completion of the sludge removal and disposal, the Permittee shall complete the following closure measures.</p> <p>a) Remove all lines leading to and from the impoundments, or permanently plug and abandon the lines in place.</p>

#	Terms and Conditions
	<p>b) Remove or demolish any other wastewater system components and re-grade area with suitable fill to blend with surface topography, promote positive drainage and prevent ponding.</p> <p>c) Characterize, remove, and dispose of all solids from the impoundments in accordance with local, state, and federal regulations, and maintain a record of solids transported for off-site disposal, including the volume of solids transported and the disposal location.</p> <p>d) Remove and dispose of the impoundment liners at a solid waste facility. If there is evidence of contaminated soil below the liners, assess the impact, report that assessment to NMED, and mitigate the impacts following NMED approval.</p> <p>e) Fill the impoundments with suitable fill.</p> <p>f) Re-grade the impoundment site and the locations of ancillary equipment, e.g., influent piping, to blend with surface topography, promote positive drainage and prevent ponding.</p> <p>The Permittee shall continue groundwater monitoring until the Permittee meets the requirements of this condition met and groundwater monitoring confirms for a minimum of eight consecutive quarterly groundwater sampling events that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC. This period is referred to as “post-closure.”</p> <p>If at any time monitoring results show an exceedance of a groundwater quality standard in Section 20.6.2.3103 NMAC, the Permittee shall implement the Contingency Plan required by this Discharge Permit.</p> <p>Following notification from NMED that the Permittee may cease post-closure monitoring, the Permittee shall plug and abandon the monitoring wells in accordance with the attached Monitoring Well Guidance.</p> <p>When the Permittee has met all closure and post-closure requirements and verified appropriate actions with date stamped photographic evidence or an associated NMED inspection, the Permittee may submit to NMED a written request, including photographic evidence, for termination of the Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection D of 20.6.2.4103 NMAC, 40 CFR Part 503]</p>

F. GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
46.	<p>RECORD KEEPING - The Permittee shall maintain a written record of the following:</p> <ul style="list-style-type: none"> Information and data used to complete the application for this Discharge Permit;

#	Terms and Conditions
	<ul style="list-style-type: none">• Information, data, and documents demonstrating completion of closure activities;• Any releases (commonly known as “spills”) not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC;• The operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater;• Facility record drawings (plans and specifications) showing the actual construction of the Facility and bear the seal and signature of a licensed New Mexico professional engineer;• Copies of logs, inspection reports, and monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit;• The volume of wastewater or other wastes discharged pursuant to this Discharge Permit;• Groundwater quality and wastewater quality data collected pursuant to this Discharge Permit;• Copies of construction records (well log) for all sampled groundwater monitoring wells pursuant to this Discharge Permit;• The maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and• Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including:<ul style="list-style-type: none">○ the dates, location and times of sampling or field measurements;○ the name and job title of the individuals who performed each sample collection or field measurement;○ the sample analysis date of each sample○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis;○ the analytical technique or method used to analyze each sample or collect each field measurement;○ the results of each analysis or field measurement, including raw data;○ the results of any split, spiked, duplicate or repeat sample; and○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. <p>The Permittee shall maintain the written record at a location accessible to NMED during a Facility inspection for the lifetime of the Discharge Permit. The Permittee shall make the record available to the department upon request.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>

#	Terms and Conditions
47.	<p>SUBMITTALS – The Permittee shall submit both a paper copy and an electronic copy of all notification and reporting documents required by this Discharge Permit, e.g., monitoring reports. The Permittee shall submit paper and electronic documents to the NMED Permit Contact identified on the Permit cover page.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
48.	<p>INSPECTION and ENTRY – The Permittee shall allow NMED to inspect the Facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which any maintained records required by this Discharge Permit, the regulations of the federal government, or the WQCC are located.</p> <p>The Permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.</p> <p>No person shall construe anything in this Discharge Permit as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations.</p> <p>[Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]</p>
49.	<p>DUTY to PROVIDE INFORMATION - The Permittee shall, upon NMED’s request, allow for NMED’s inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records.</p> <p>[Subsection D of 20.6.2.3107 NMAC]</p>
50.	<p>MODIFICATIONS and/or AMENDMENTS – In the event the Permittee proposes a change to the Facility or the Facility’s discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water contaminants received, treated or discharged by the Facility, the Permittee shall notify NMED prior to implementing such changes. The Permittee shall obtain NMED’s approval (which may require modification of this Discharge Permit) prior to implementing such changes.</p> <p>[Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]</p>
51.	<p>PLANS and SPECIFICATIONS – In the event the Permittee proposes to construct a wastewater system or change a process unit of an existing system such that the quantity</p>

#	Terms and Conditions
	<p>or quality of the discharge will change substantially from that authorized by this Discharge Permit, the Permittee shall submit construction plans and specifications of the proposed system or process unit to NMED for approval prior to the commencement of construction.</p> <p>In the event the Permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the Permittee shall report such changes (including the submission of record drawings where applicable) to NMED prior to implementation.</p> <p>[Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p>
52.	<p>CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the Permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the Permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]</p>
53.	<p>CRIMINAL PENALTIES – No person shall:</p> <ul style="list-style-type: none"> • Make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or maintained under the WQA; • Falsify, tamper with or render inaccurate any monitoring device, method or record maintained under the WQA; or • Fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation. <p>Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is</p>

#	Terms and Conditions
	<p>guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]</p>
54.	<p>COMPLIANCE with OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the Permittee of the obligation to comply with any other applicable federal, state, and/or local laws, regulations, zoning requirements, nuisance ordinances, permits or orders.</p> <p>[NMSA 1978, § 74-6-5.L]</p>
55.	<p>RIGHT to APPEAL - The Permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues raised and the relief sought. Unless the Permittee files a timely petition for review, the decision of NMED shall be final and not subject to judicial review.</p> <p>[20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]</p>
56.	<p>TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this Facility or any portion thereof, the Permittee shall:</p> <ul style="list-style-type: none"> • Notify the proposed transferee in writing of the existence of this Discharge Permit; • Include a copy of this Discharge Permit with the notice; and • Deliver or send by certified mail to NMED a copy of the notification and proof that the proposed transferee has received such notification. <p>The Permittee shall continue to be responsible for any discharge from the Facility, until both ownership and possession of the Facility have been transferred to the transferee.</p> <p>[20.6.2.3111 NMAC]</p>
57.	<p>PERMIT FEES – The Permittee shall be aware that the payment of permit fees is due at the time of Discharge Permit approval. The Permittee may pay the permit fees in a single payment or they may pay the fee in equal installments on a yearly basis over the term of the Discharge Permit. The Permittee shall remit single payments to NMED no later than</p>

#	Terms and Conditions
	<p>30 days after the Discharge Permit issuance date. The Permittee shall remit initial installment payments to NMED no later than 30 days after the Discharge Permit issuance date; with subsequent installment payments remitted to NMED no later than the anniversary of the Discharge Permit issuance date.</p> <p>Permit fees are associated with <u>issuance</u> of this Discharge Permit. No person shall construe anything in this Discharge Permit as relieving the Permittee of the obligation to pay all permit fees assessed by NMED. A Permittee that ceases discharging or does not commence discharging from the Facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. NMED shall suspend or terminate an approved Discharge Permit if the Permittee fails to remit an installment payment by its due date.</p> <p>[Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]</p>

draft



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Facility Information

Facility Name	Hobbs Generating Station
Discharge Permit Number	DP-1620
Legally Responsible Party	Lea Power Partners, LLC Ludovic Pasqualinotto, Facility Representative
	98 N. Twombly Lane Hobbs, New Mexico 88240 +575-397-6706

Treatment, Disposal and Site Information

Primary Waste Type	Industrial
Facility Type	Power Plant

Discharge Locations

Type	Designation	Description & Comments
Impoundment	West	Double synthetically-lined storage impoundment equipped with leak detection system
Impoundment	East	Double synthetically-lined storage impoundment equipped with leak detection system
Irrigation Area	Irrigation Area	Native vegetation totaling 58.62 acres and irrigated using a single center pivot system

Flow Metering Locations

Type	Designation	Description & Comments
Totalizing Flow Meter TFM-1	Impoundment Meter	Flow meter located on the transfer line between the generating station and the storage impoundments
Totalizing Flow Meter TFM-2	Irrigation Meter	Flow meter located on the transfer line between the storage impoundments and the irrigation area
Totalizing Flow Meter TFM-3	Supplemental Well Meter	Flow meter located at the supplemental irrigation well

Ground Water Monitoring Locations

Type	Designation	Description & Comments
Monitoring Well	MW-1	Located hydrologically upgradient of the storage impoundments
Monitoring Well	MW-2	Located downgradient of the West Pond
Monitoring Well	MW-3	Located downgradient of the East Pond



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Monitoring Well	MW-4B	Located hydrologically upgradient of the storage impoundments and downgradient of the land application area. Installation required by this permit to replace MW-4A, which is dry
-----------------	-------	--

Depth-to-Ground Water 50-70 feet
Total Dissolved Solids (TDS) 340 mg/L

Permit Information

Original Permit Issued April 4, 2007
Permit Renewal and Modification December 19, 2011
Permit Renewal July 6, 2017

Current Action **Renewal**
Application Received December 14, 2021
Public Notice Published [Not yet published]
Permit Issued (Issuance Date) [Not yet issued]
Permitted Discharge Volume 165,000 gallons per day

NMED Contact Information

Mailing Address Ground Water Quality Bureau
P.O. Box 5469
Santa Fe, New Mexico 87502-5469

GWQB Telephone Number (505) 827-2900

NMED Lead Staff Kathleen Murphy
Lead Staff Telephone Number (505) 660-7567
Lead Staff Email Katheen.Murphy@env.nm.gov or pps.general@env.nm.gov