



New Mexico Environmental Department
 Petroleum Storage Tank Bureau
 2905 Rodeo Park Drive East, Bldg. 1
 Santa Fe, NM 87505
 (505) 476-4397
 Send test reports to:
PSTB.Compliance@state.nm.us

Automatic Tank Gauge (ATG) System and Interstitial or Sump Sensor Inspection and Testing

| |
|----------------------|
| Date Test Conducted: |
|----------------------|

New Mexico PST Facility and Owner Information

| | | | |
|------------------|--------------|----------------|-----------|
| Facility Name | Facility ID# | Owner Name | Owner ID# |
| Facility Address | | Owner Address | |
| City | Zip Code | City | Zip Code |
| County | Phone # | E-mail Address | Phone # |

Contractor/Technician Information

| | | | |
|---|---------------------------------|---------------------|-------------------------------|
| Technician's Name | Technician Certification Number | Company | |
| City | State | Zip Code | Phone # |
| Manufacturer Certification (i.e. Veeder-Root or Franklin Fueling) | | Certification Level | Certification Expiration Date |

ATG Inspection/Testing Information

Tank Number

| | | | | |
|--|--|--|--|--|
| Regulated Substance or Product Stored | | | | |
| ATG Brand and Model | | | | |
| ATG probe or stem model number | | | | |
| ATG probe or stem serial number | | | | |
| 1. Tank Volume, gallons | | | | |
| 2. Tank Diameter, inches | | | | |
| 3. After removing the ATG Probe from the tank, has it been inspected and any damage or missing parts replaced? | | | | |
| 4. Tank stick used to check water and product level at ATG probe riser? | | | | |
| 5. Float moves freely on the stem without binding? | | | | |
| 6. Does the fuel float level agree with the value programmed into the console? | | | | |
| 7. Does the water float level agree with the value programmed into the console? | | | | |

